HPK/2012/0094
13 MAR 2012

MITRED CORNICE RETURN GLUED + SUNK-SCREWED

APPROX. 600MM

EX 150 x 50

15 15 38 RADIUS 15

cornice moulding profile

PAINTED PLY SIGNBOARD

SEAL MITRED JOINTS IN TRIM

CORBEL

140

225

CODE 4 LEAD FLASH, WEDGED + SEALED INTO GROOVE 25 MM DEEP MIN.

175 x 38 CANOPY TOP BOARD, SUNK-SCREWED

300 WIDE CODE 5 LEAD COVER, WITH CENTRAL "ROLL" JOINT

CORNICE SECTION SUNK-SCREWED

75 x 50 S.W. FRAME; (COVERS STEEL BEAM), WITH VERTICALS @ 1·2 M. C/S

PRESUMED STEEL BEAM

12 MM EXT. PLY SIGNBOARD

44 x 19 HARDWOOD TRIM, SPLAY TO TOP + BOTTOM EDGES; SET IN SEALANT, + SINK NAIL

12 EXT. PLY SOFFIT

94

(CORBEL BEYOND)

50 MM RADIUS

GLAZING

(FACE OF TIMBER PILASTER BEYOND)

(STONEWORK FACE BEYOND)

PAINTED TIMBER PILASTER, WITH DIAMOND MOTIF AS DWG. 1

GLAZING

CILL

existing stone plinth

RENDERED PANEL

DOUBLE

CILL, EX 200 x 75 MM HARDWOOD, WITH 38 MM RADIUS BULLNOSE

DPC

FIX CILL THROUGH REBATE INTO BRICK

RAISE PANEL BY 150MM WITH 2 COURSES OF CONC. BRICKS

2-COAT CEMENT-BASED RENDER, 1:6 MIX, PLASTICISED/S.B.R.: SMOOTH FINISH.

existing brick panel

pavement

glazing:
DOUBLE, TOUGHENED, ARGON-FILLED "K" GLASS: 16 MM GAP: SEAL REBATES + BEADS WITH PRIMER BEFORE FIXING: BED ON COMPOUND WITH SETTING BLOCKS + SPACERS TO SUIT. INTERNAL BEADS SUNK-PINNED @ 150 MM C/S

12MM PLY FACING, SCREWED

50MM "KINGSPAN" IN VOID

75 x 50 S.W. BATTEN, FIXED TO STONE RETURN VIA HEAVY DUTY FIXINGS

stone wall

60MM

SEALANT

SEAL

PAINTED TIMBER CILL

EX 250 x 38 S.W. PILASTER SUNK SCREWED + FILLED TO S.W. FRAMING

WINDOW FRAME (JAMBS + MULLIONS) FROM 100 x 63 MM S.W.
- REAR-GLAZED, WITH 16 x 50MM REBATE;
- FRONT SPLAYS 60° (25 x 15 MM)

EX 100 x 50

EX 100 x 75

38 RADIUS

CILL

DOORWAY MULLION/CORNER TO BE GLUED UP FROM PIECES AS SHOWN

SEAL AND SCREW ACROSS MITRED CILL

Joinery:
ALL JOINERY (EXCEPT WHERE NOTED AS "HARDWOOD") TO BE 5THS / UNSORTED REDWOOD, EITHER PROTIM/"VAC-VAC" OR SITE-TREATED WITH PRESERVATIVE.

FIXINGS GENERALLY TO BE RUST-PROOF (ZINCED/STAINLESS STEEL EXTERIOR WORK ALL TO BE EITHER SET IN SEALANT OR WATERPROOF GLUE

James Thornely Architect; "Lymbrook", Whitehough, Chinley, HIGH PEAK, SK23 6EJ.
e-jthornely@hotmail.com
p-01663 750415

Project Title: Shopfront; 6 Market St., Chapel-e.-L. Frith

Dwg. Title: Joinery details

Dwg. No. 1201/2

Rev. B

Scale: 1:5

Date: March '12