PROPOSED FRONT ELEVATION 1:50

1 THE OLD TENNIS COURTS



THE PROPOSAL RELATES TO THE CONSTRUCTION OF A NEW SINGLE STOREY SIDE PORCH EXTENSION (CONSIDERED A PERMITTED STRUCTURE UNDER BUILDING REGS AS INDEPENDANTLY HEATED AND THERMALLY BROKEN FROM THE HOST DWELLING). THE EXTENSION IS TO BE CONSTRUCTED IN MATCHING MATERIALS TO MAIN HOUSE WITH RECON STONE, STONE HEADS/CILLS/AND QUOIN DETAILS TO MATCH. ROOF COVERINGS OF VILLA DEL REY SLATES TO MATCH

NEW STRIP FOOTINGS ARE TO BE MIN 600x300 AT DEPTH OF 1000mm OR TO SUIT GROUND CONDITIONS. FOUNDATION WALLS TO BE 100mm 7N HEMELITE (OR SIMILAR). 100mm WEAK MIX CONC. FILL UPTO 225mm BELOW DPC. NEW FLOOR CONSTRUCTED AS PER A GROUND BEARING SLAB MAKE UP. 1200g DPM, 100mm XTRATHERM XT/UF AND 100mm SCREED OVER (500g ISOLATING MEMBRANE). ALLOW FOR 25mm PERIMETER INSULATION AT ALL JUNCTIONS TO PREVENT COLD BRIDGING. MAKE-UP LAID TO LINE IN WITH EXISTING HOUSE FLOOR LEVEL. TAPE AND SEAL ALL NEW AND EXISTING DAMP COURSES.

NEW STRUCTURE IS TO BE 300 O/A WITH 100mm OUTER RECON STONE TO MATCH THE EXISTING HOUSE, 100mm CAVITY WITH 60mm XTRATHERM POLYISO XT INSULATION MAINTAINING AIR GAP. 100mm 7N HEMELITE OR SIMILAR INTERNAL BLOCKWORK WITH 12.5mm PBD ON DABS.
ROOF OVER TO BE RAFTERS (150x50) AT 450mm ctrs BUILT OFF 100x75 WALLPLATE (STRAPPED TO WALL AT 1200ctrs). ROOF LINE TO BE INSULATED WITH 40mm SUPERQUILT BETWEEN AND BELOW RAFTER LINE AND FINISHED WITH SLATES FINISH TO MATCH MAIN HOUSE. ALLOW FOR CROSS FLOW VENTILATION AND BREATHABLE MEMBRANE AS OUTLINED IN COVERING NOTES. VELUX ROOFLIGHTS TO BE GGL C04 UNITS - 550x980 (CONSERVATION)

ALL HARDWOOD WINDOWS AND DOORS (PAINTED WHITE TO MATCH) ARE TO BE ARGON SOFTCOAT LOW 'E' DOUBLE GLAZED UNITS WITH 'U' VALUE OF 1.2. ALLOW FOR PROPRIETORY CAVITY CLOSERS TO ALL OPENINGS AND WEEP HOLES WHERE APPLICABLE. ALLOW FOR A CATNIC CAVITY LINTOL OVER OPENINGS RELEVANT TO THE STRUCTURAL OPENINGS.

ALL ELECTRICAL WORKS ARE TO UNDERTAKEN IN ACCORDANCE WITH PART P CERTIFICATION AND TO THE APPROVAL OF BUILDING CONTROL.
HEAT/SMOKE DETECTORS ARE TO BE INSTALLED AND MUST BE INTERLINKED WITH MAINS BATTERY BACK UP

DWG: PROPOSED
THE OLD TENNIS COURTS
OFF LASCELLES ROAD, BUXTON

REVISIONS:

1:50	CHECKED:
DATE: FEB'13	DRAWN:

©THIS DRAWING AND THE BUILDING WORKS DEPICTED ARE THE COPYRIGHT OF AJS ARCHITECTURE AND MAY NOT BE REPRODUCED OR AMENDED EXCEPT BY WRITTEN PERMISSION. NO LIABILITY WILL BE ACCEPTED FOR AMENDMENTS MADE BY OTHER PERSONS. - DO NOT SCALE OFF DRAWING. CONFIRM ALL DIMS ON SITE

A.J.S ARCHITECTURE
32 carr road.
buxton.
derbyshire.
sk17 6wf.
h: 01298 26062
m: 07794 400237



PROPOSED 03

1,TENNIS COURTS