

General Notes

1. DO NOT SCALE.
2. This drawing is to be read in conjunction with all other relevant drawings and details.
3. Should there be any conflict between the details indicated on this drawing and those indicated on other drawings the Engineer should be informed PRIOR to construction on site.
4. Until technical approval has been obtained from the relevant Authority, it should be understood that all drawings issued are Preliminary and NOT for construction. Should the contractor commence site work prior to such approval being given, it is entirely at his own risk.
5. All dimensions are in millimetres unless otherwise stated.
6. The BSP Hazard Identification and Risk Assessment (HIRA) for this project has been completed and is to be reviewed by the contractor PRIOR to the commencement of any works on site.

Table 2			Min Thickness of Sub Base Required (mm) (consolidated in accordance with MCHW vol 1 Clause 801, table 8/7)
CBR Value	Sub Base Thickness	OR Sub Base with Capping	
less than 2%	540 (Geotextile required)	150	600
2 - 3 %	390		
3 - 4 %	290	150	350
4 - 5 %	230		
5 - 6 %	180		
6 - 7 %	140		
> 7 %	100	Not Applicable	

