## 22 COMPTON GROVE, BUXTON PROPOSED SIDE ELEVATION 1:50

## ALL ROOF COVERINGS ARE TO MATCH EXISTING AT ASSUMED 35deq PITCH WITH PLAIN TILES WITH TYVEK BREATHABLE MEMBRANE. GUTTERING TO BE IN BLACK PLASTIC WITHOUT SOFFIT BOARD AS PER EXISTING <del>1</del>300 2100 1350 1200 4950 TO MATCH TO TOP OF GUTTER LINE

WALL CONSTRUCTION TO BE CAVITY WORK 300 0/A WITH 100MM FACED STONE (CONC) TO MATCH EXISTING, 100 CAVITY WITH 60mm PARTIAL FILL XTRATHERM INSULATION AND 100 7N INTERNAL BLOCK (HEMELITE OR EQUIVALENT ETC). ALLOW FOR ALL RELEVANT WALL TIES IN ACCORDANCE WITH ATTACHED SPECIFICATION. INTERNAL DRY LINED PLASTERBOARD, TAPED AND SEALED TO FINISH INTERNALLY. THE HOUSE IS ONLY 2 YEARS OLD IT IS ASSUMED THE EXISTING STRUCTURE BELOW IS SIMILAR AND STILL SHOW COMPLIANCE WITH CURRENT U VALUES. NB ADJUST DIMS FOR STRUCTURE INTERNALLY ACCORDINGLY IF EXISTING STRUCTURE VARIES TO NEW. ALL NEW WINDOWS ARE TO BE IN WHITE UPVC DOUBLE GLAZED UNITS TO MATCH WITH OPENING CASEMENTS FOR ESCAPE PURPOSES AS PER EXISTING. OF THE APPLICATION IS TO BUILD UP OVER THE EXISTING SINGLE STOREY ELEMENT TO THE REAR OF THE KITCHEN (BUILT AS PART OF THE HOUSE WHEN NEW 2 YEARS AGO). THE FIRST FLOOR IN WILL ALLOW FOR AN EXTENDED REAR BEDROOM AND INTERNAL ALTERATIONS TO ALLOW AN INCREASE IN THE MAIN BATHROOM WITH A NEW SPA BATH TO BE INCORPORATED AND ANY RELEVANT O THE SUITE. THE EXTENSION WILL NOT EXTEND THE EXISTING BUILDING LINE AND SIMPLY USES THE SAME FOOTPRINT TO BUILD UP OFF — WERE THE BUILDING OVER 2000mm FROM THE YTHESE WORKS WOULD BE REGARDED AS PERMITTED DEVELOPMENT. IT IS SIMPLY THE FACT THAT THE BUILDING LINE SITS SLIGHTLY WITHIN THIS DIM THAT THE APPLICATION IS SUBMITTED FOR

WALL TAKEN UP TO 100X100 WALLPLATE STRAPPED TO WALL BELOW AT 1200 CTRS TO SUPPORT 150x50 C16 RAFTERS AT 450ctrs AT ANGLE OF 35deg ASSUMED TO MATCH EXISTING. THIS APPLIES TO HIP SECTION AND LEAN—TO AREA OVER EXISTING, ALSO ALLOW FOR GIRDER TRUSSED RAFTERS BETWEEN TO ALLOW FOR SUPPORT STRUCTURE TO BOTH THE NEW HIP RAFTERS AND ALSO TO HANG THE EXISTING RAFTER ENDS INTERNALLY TO ALLOW FOR THE REMOVAL OF THE WALL STRUCTURE BELOW WITHOUT STEELWORK.

ROOF VOID TO BE INSULATED WITH 300mm CROSS LAY ROCKWOOL ROOF COVERINGS ARE TO VALLEY, ASSOCIATED LAYBOARDS AND DAMP MEMBRANE ETC. BE TYVEK BREATHABLE MEMBRANE WITH PLAIN TILES TO MATCH 풀 OF EXISTING. ALLOW FOR CODE 5 LEAD

22 COMPTON GR PROPOSED 09

W III	lic n	UIMIN	^ 1	UD TI	E DII	III DIMO	WADIVE	DEDICTE	D ADE	тиг	ΛΛΠV	DIALIT	۸۲ .	110	ADOLL	ITEC	THINE			Ī
ווע	113 U	KAWIN	υA	זו עוז	E BU	ILVING	WORKS	VERTUIL	u akt	. Inc	CUPT	KIUHI	UT /	M	AKUN	ルル	IUKL			
AND	MAY	MOT	RF I	REPRO	DIICE	D OB	AMENDED	FYCEPI	r RY '	WRITTE	N PE	1221MG	ON.	NΛ	IIARII	ITY	WILL	RF .	ACCEPTED	ı
MIL	mr	IVVI	<b>DL</b>	VEI IVO	DOOL	U VI	MILITULE	LIVE	יטי	with th		I WII O	VII.	110	LINUIL		WILL	DL .	MOOLI ILD	1
EVD	AME	MUMEN	TC I	MADE	DV A	TUED	PERSONS	_ M	MAT .	CUNIC	VEE	DDAWI	MC .	VVM	CIDA	ALL	MMC	ΛN	CITE	
rvk	AMIL	MUNICI	113	MAVE	DIV	HILK	しにいついいつ	, - W	NVI -	JUALL	vrr	DEVAN	nυ,	VVII	LIKW	ΑЩ	NIMO	VN	JIIL	
																				-

A.J.S A	ARCHITE	ECTURE
力力	3.7	
	n: 01298 07794 4	32 49
	98 26062 1 400237	2 carr road. buxton. derbyshire. sk17 6wf.
	236	road Shire Swife

DATE:		
FEB'15	1:50	
5		
DRA	웊	
AWN:	CHECKED:	

DWG: PROPOSED
22 COMPTON GROVE
BUXTON
REVISIONS: