

High Peak Borough Council
Planning
Town Hall
Glossop
Derbyshire

02 August 2015

Dear Sirs

Cattery 47 Platt Street Padfield
Appeal ref: APP/H1033/W/15/3005699

Please find below the specification for ventilation as required by condition no.3 of consent reference: HPK/2014/0615 and appeal reference APP/H1033/W/15/3005699 dated 22nd June 2015.

The proposed fan system is as follows:

Expelair 150mm fan

Item reference GX6 90800AW

Extraction rate = 266m³ per hour

Noise level = 37dba at 3m

Powered from mains supply then controlled by a timer switch for optimum control of ventilation.

Vented directly in to the owner's garden, air intake from the side of the building inside the owner's property.

Xpelair GX6 EC2 & GXC6 EC2

Kitchen and Utility room axial fans with UltraEC technology



20 Bath Street Nottingham NG1 1DF

0 7 9 6 8 3 2 6 3 3 1

mark@camplan.co.uk
www.camplan.co.uk

	GX6 EC2	GXC6 EC2
Reference Number	92294AW	92295AW
Longlife UltraEC motor	Yes	Yes
Selectable speeds at installation	284m ³ /h = 10.6W 144m ³ /h = 7.1W	284m ³ /h = 7.9W 144m ³ /h = 3.4W
Electric Power rating (W)	10.6	7.9
Sound pressure level (dB(A) @3m)	30.3	30.3
Integral electro-thermal shutter	Yes	
Integral pullcord shutter		Yes
Hole diameter in window (mm)	184	184
Hole diameter using wall kit (mm)	203	203
Weight (kg)	1.9	1.9
Guarantee (Years UK)	5	5

Regards

Yours faithfully



Mark Strawbridge MRTPI IHBC (A)IfA