



Proposed Door Architrave Detail
1:5 @ A1

- NOTES:**
- 1 - All softwood door frames unless indicated otherwise.
 - 2 - Fire doors: Include for Intumescent strip (30min doors - reference Sealmaster N30 or equal) and u/s of door leaf to receive Intumescent strip seal.
 - 3 - Door leaf to be solid core softwood, paint grade unless indicated otherwise, 44mm thick for 30 minutes fire resistance. HW flipped all round. Panel moulds to match existing door leaves.
 - 4 - Vision panels to 30min fire doors to be glazed with 7mm thick Pilkington Pyrodur Plus 30 internal grade glass set in hardwood beads screw fix to frame, set in Intumescent paste.
 - 5 - Allow for 10mm clearance below door leaf in carpeted areas.
 - 6 - All stainless steel kickplates to be dent free.
 - 7 - Hinges to be recessed into frame, top hinge to be fitted 300mm from top edge of door leaf. All fire door hinge material should be having a melting point of at least 800-degrees Celsius.

All door furniture to match existing hotel bedroom furniture

PRESTWICH DESIGN GROUP is a trading name of BRITANNIAHOTELS LTD.

Notes:-

**ALL DIMENSIONS TO BE CHECKED ON SITE.
DISCREPANCIES MUST BE REPORTED TO PDG.
IF IN DOUBT - ASK**

Rev.		Date		Description		By		Project	
		Palace Hotel Palace Road, Buxton							
		Content Internal Door Details							
Scale 1:5 @ A3		Drawing no. P350.NA.703		Rev. /		Drawn by C.I.H.		Date October 2015	
<div>PRESTWICH DESIGN GROUP</div> <div>2ND FLOOR ROAD, HALE, CHESHIRE Tel: 0161 904 6000 Fax: 0161 904 6001</div>									

Proposed Door Architrave Elevation

1:5 @ A1

