


01 PROPOSED SMALL POWER LAYOUT
E300 1:100 scale@A1 size

NOTES:

The Electrical Contractor shall include for 2No 32A SP&N IP65 Rotary Isolator for the AC Units, located externally above the Kitchen roof.

KEY:-

- TP&N DISTRIBUTION BOARD
- MCCB PANEL BOARD
- SP&N DISTRIBUTION BOARD
- SP&N ROTARY ISOLATOR
- 3 PIN SOCKET WITH ROTARY ISOLATOR
- SUB METER
- TWIN SWITCHED SOCKET OUTLET
- FUSED SPUR
- 4 COMPARTMENT FLOOR BOX WITH 2NO TWIN SWITCHED SOCKET & 1 NO DOUBLE DATA POINT
- EXTENT OF WORKS AREA



02 LOCATION PLAN
E300/NTS@A1 size

Client



Site

PAVILLION GARDENS, BUXTON
DERBYSHIRE, SK17 6BE

HIGH PEAKS
BOROUGH CONCIL

Client

HIGH PEAKS BOROUGH CONCIL
BUXTON TOWN HALL
MARKET PLACE, BUXTON
DERBYSHIRE, SK17 6EL
+44 (0)345 1297777

client@internet.com
http://www.highpeak.gov.uk

Suitability Description:

FOR APPROVAL

Designed	M.LEATHER	Date	22-JAN-16	Signed	
Drawn	C.METCALF	Date	22-JAN-16	Signed	
Checked	M.LEATHER	Date	22-JAN-16	Signed	
Approved	P.NICHOLSON	Date	22-JAN-16	Signed	
Scale:	1:100	Datum:			
Original Size:	A1	Grid:			
Suitability Code:		Project Number:	33198102		

PROJECT:

OCTAGON RING BEAM
M&E SERVICES UPGRADES

TITLE:

PROPOSED SMALL POWER
LAYOUT



Registered office:
ARCADIS House
34 York Way
London
N1 9AB

Coordinating office:
ARCADIS House
34 York Way
London
N1 9AB
Tel: 44 (0)20 7812 2000

www.arcadis.com

Drawing Number:

E300

Revision:

-