



**Key:**

- 125KF - 255x125mm PCC half battered kerb to BS7263, laid with 125mm upstand.
- 1.8m High Green Palisade Fence to BS1772 Part 12 2006. To be erected by fencing contractor, not groundworks contractor
- Tanker Hardstanding Access Spec:  
WC - 200mm Thick Reinforced Concrete  
SB - 500mm Type 1 Granular Sub Base
- Compound Hardstanding Spec:  
200mm Thick Reinforced Concrete

All dimensions to be checked on site. Do not scale off drawing. This drawing is the copyright of Westleigh Partnerships Ltd and not to be reproduced without their permission.

Revision: \_\_\_\_\_ Date: \_\_\_\_\_

Plot 14  
Type A  
FFL 15



Status:	Tender
Project:	Surrey Street, Glossop
Title:	Pumping Station Compound Details
Drawing No:	WD/243/32
Scale:	1:100 @ A3
Date:	26/08/16
Drawn:	MH
Approved:	LC

Westleigh Partnerships Ltd  
Tudorgate, Grange Business Park, Enderby Road  
Whetstone, Leicestershire LE8 6EP  
t: 0116 277 3324 | f: 0116 278 4581  
westleigh.co.uk