

Hi John,

We wouldn't have an issue with the general proposal in line with HSE) but obviously need some sort of guarantee it will happen. I would suggest tweaking Matt's condition to something like this, so it has to be submitted.

**Asbestos Survey**

Demolition of the existing buildings should not take place until an asbestos removal method statement has been prepared in accordance with the procedures outlined in HSG264 (<http://www.hse.gov.uk/pUbns/priced/hsg264.pdf>) and submitted to the local planning authority for approval. Once approved, all demolition activities on the site should be carried out in accordance with the agreed asbestos removal method statement.

Thanks

Dan

---

Dr. Daniel McCrory

Senior Pollution Officer

Regulatory Services

Staffordshire Moorlands District Council & High Peak Borough Council

Moorlands House

Stockwell Street

Leek

ST13 6HQ

Direct Dial: 01538 395400 Ext: 4413

Mobile: 07736380776