

From: joe.drewry@environment-agency.gov.uk
To: [Planning \(HPBC\)](#)
Subject: Environment Agency Response to: HPK/2017/0427
Date: 24 August 2017 07:49:22
Attachments: [PlanningProposal.rtf](#)

The proposal has been reviewed and I enclose the Environment Agency's comments on:
Higher Brook House Farm Brook House Drive
Fairfield
Buxton

LPA ref: HPK/2017/0427

Information in this message may be confidential and may be legally privileged. If you have received this message by mistake, please notify the sender immediately, delete it and do not copy it to anyone else.

We have checked this email and its attachments for viruses. But you should still check any attachment before opening it.

We may have to make this message and any reply to it public if asked to under the Freedom of Information Act, Data Protection Act or for litigation. Email messages and attachments sent to or from any Environment Agency address may also be accessed by someone other than the sender or recipient, for business purposes.

To report this email as SPAM, please forward it to spam@forcepoint.com

High Peak Borough Council
Development Control
Municipal Buildings Market Place
Glossop
Derbyshire
SK13 8AF

Our ref: LT/2017/122489/01-L01
Your ref: HPK/2017/0427
Date: 24 August 2017

Dear Sir/Madam

**ERECTION OF A 15 KENNEL CANINE BOARDING KENNELS AND ASSOCIATED
ACCOMMODATION
HIGHER BROOK HOUSE FARM BROOK HOUSE DRIVE FAIRFIELD BUXTON**

Thank you for referring the above application which was received on 23rd August 2017.

Environment Agency Position

The Agency has no objections to the proposed development but wishes to make the following comments.

Government guidance contained within the National Planning Practice Guidance (Water supply, wastewater and water quality – considerations for planning applications, paragraph 020) sets out a hierarchy of drainage options that must be considered and discounted in the following order:

1. Connection to the public sewer
2. Package sewage treatment plant (adopted in due course by the sewerage company or owned and operated under a new appointment or variation)
3. Septic Tank

Foul drainage should be connected to the main sewer. Where this is not possible, under the Environmental Permitting Regulations 2010 any discharge of sewage or trade effluent made to either surface water or groundwater will need to be registered as an exempt discharge activity or hold a permit issued by the Environment Agency, addition to planning permission. This applies to any discharge to inland freshwaters, coastal waters or relevant territorial waters.

Please note that the granting of planning permission does not guarantee the granting of an Environmental Permit. Upon receipt of a correctly filled in application form we will carry out an assessment. It can take up to 4 months before we are in a position to decide whether to grant a permit or not.

Domestic effluent discharged from a treatment plant/septic tank at 2 cubic metres or less to ground or 5 cubic metres or less to surface water in any 24 hour period must comply with General Binding Rules provided that no public foul sewer is available to serve the development and that the site is not within a Groundwater Source Protection Zone.

Environment Agency
Trent Side North, West Bridgford, Nottingham, NG2 5FA.
Customer services line: 03708 506 506

www.gov.uk/environment-agency

Cont/d..

A soakaway used to serve a non-mains drainage system must be sited no less than 10 metres from the nearest watercourse, not less than 10 metres from any other foul soakaway and not less than 50 metres from the nearest potable water supply, spring or borehole.

Where the proposed development involves the connection of foul drainage to an existing non-mains drainage system, the applicant should ensure that it is in a good state of repair, regularly de-sludged and of sufficient capacity to deal with any potential increase in flow and loading which may occur as a result of the development.

Where the existing non-mains drainage system is covered by a permit to discharge then an application to vary the permit will need to be made to reflect the increase in volume being discharged. It can take up to 13 weeks before we decide whether to vary a permit.

Further advice is available at:

[PPG4: Sewage treatment and disposal where there is no foul sewer](#)
[Septic tanks and treatment plants: permits and general binding rules](#)

Yours faithfully

Mr Joseph Drewry
Planning Advisor

Direct dial 02030 253277

Direct e-mail joe.drewry@environment-agency.gov.uk