



Derbyshire Fire & Rescue Service

Making Derbyshire Safer

HPBC Planning Department
PO Box 136
Buxton
SK17 1AQ

planning@highpeak.gov.uk

Contact Name & Address
Stuart Crayon

North Area – Buxton Office
Buxton Fire & Rescue Centre
Staden Lane
Buxton
Derbyshire
SK17 9RZ

Our Reference
J409-767/SC/KP

Your Reference
HPK/2017/0534

Date
13 October 2017

Contact Telephone No & Ext
01298 608720

Dear Sir/Madam

Re: RESIDENTIAL DEVELOPMENT LAND OFF HAYFIELD ROAD NEW MILLS

Thank you for your email regarding the above proposed development.

The Fire and Rescue Authority strongly recommend the Installation of a Domestic Sprinkler System in the proposed premises, however should you choose not to install a Domestic Sprinkler System at this stage, the Fire and Rescue Authority would like to recommend that you provide a minimum 32mm water supply capable of delivering the required volumes which would allow an installation to be carried out easier and at less cost should this be proposed in the future.

If I can be of any further assistance to you in this matter please do not hesitate to contact me.

Yours faithfully

Authorised Fire Safety Inspecting Officer
And on behalf of the Derbyshire Fire and Rescue Authority

email: reception@derbys-fire.gov.uk
www.derbys-fire.gov.uk

Chief Fire Officer / Chief Executive
Terry McDermott MA

