

GROUND

SCALE 1:100





PROPOSED PLAN



SCALE 1:200



FIRE RECESS



FLUE CONSTRUCTION

SCALE 1:20



BACKGROUND AND PURGE VENTILATION

Background ventilation - Controllable background ventilation via trickle vents to BS EN 13141-3 within the window frame to be provided to new habitable rooms at a rate of min 5000mm²; and to kitchens, bathrooms, WCs and utility rooms at a rate of 2500mm²

Purge ventilation - New Windows/rooflights to have openable area in excess of 1/20th of their floor area, if the window opens more than 30° or 1/10th of their floor area if the window opens less than 30°. Internal doors should be provided with a 10mm gap below the door to aid air circulation.Ventilation provision in accordance with the Domestic Ventilation Compliance Guide.

INTERNAL STUD PARTITIONS

100mm x 50mm softwood treated timbers studs at 400mm ctrs with 50 x 100mm head and sole plates and solid intermediate horizontal noggins at 1/3 height or 450mm. Provide min 10kg/m³ density acoustic soundproof quilt tightly packed (eg. 100mm Rockwool or Isowool mineral fibre sound insulation) in all voids the full depth of the stud.

Partitions built off doubled up joists where partitions run parallel or provide noggins where at right angles, or built off DPC on thickened concrete slab if solid ground floor. Walls faced throughout with 12.5mm plaster board with skim plaster finish. Taped and jointed complete with beads and stops.

RAINWATER DRAINAGE

New rainwater goods to be new 110mm UPVC half round gutters taken and connected into 68mm dia UPVC downpipes. Rainwater taken to new soakaway, situated a min distance of 5.0m away from any building, via 110mm dia UPVC pipes surrounded in 150mm granular fill. Soakaway to be min of 1 cubic metre capacity (or to depth to Local Authorities approval) with suitable granular fill and with geotextile surround to prevent migration of fines. If necessary carry out a porosity test to determine design and depth of soakaway.

PIPEWORK THROUGH WALLS

Where new pipework passes through external walls form rocker joints either side wall face of max length 600mm with flexible joints with short length of pipe bedded in wall. Alternatively provide 75mm deep pre-cast concrete plank lintels over drain to form opening in wall to give 50mm space all round pipe: mask opening both sides with rigid sheet material and compressible sealant to prevent entry of fill or vermin.

ELECTRICAL

All electrical work required to meet the requirements of Part P (electrical safety) must be designed, installed, inspected and tested by a competent person registered under a competent person self certification scheme such as BRE certification Ltd, BSI, NICEIC Certification Services or Zurich Ltd. An appropriate BS7671 Electrical Installation Certificate is to be issued for the work by a person competent to do so. A copy of a certificate will be given to Building Control on completion.

HEATING

Extend all heating and hot water services from existing and provide new TVRs to radiators. Heating system to be designed, installed, tested and fully certified by a GAS SAFE registered specialist. All work to be in accordance with the Local Water Authorities bye laws, the Gas Safety (Installation and Use) Regulations 1998 and IEE Regulations.

PLANS ARE TO BE READ IN CONJUNCTION WITH STRUCTURAL ENGINEERS DETAILS

IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO CHECK ALL MEASUREMENTS ON SITE PRIOR TO WORK COMMENCING

IF ON SITE CHANGES ARE TO BE MADE CONTACT PLAN DRAWER

WOOD BURNING STOVE IS TO BE INSTALLED TO MANUFACTURES SPECIFICATION AND PERMANANT VENTIALTION PROVIDED WHERE NECESSARY

M 0	1:200 2	4	6	8	10	12	14	16	18	20	[m]
M 0	1:100	2	3	4	5	6	7	8	9		[m]
M 0	1:50 0,5	1,0	1,5	2,0	2,5	3,0	3,5	4,0	4,5	 5,0	[m]
M 0	1:20 0.2	0.4	0.6	0.8	1	1.2	1.4	1.6	1.8	2	[m]

Building Regulations Plans

Single Storey Rear Extension

3 Hillside Chaple Milton Chapel-en-le-Frith High Peak SK23 0QQ

Scale - 1:100 @ A1 unless stated Drawn By - EH Date - 02.2018

Rev Description

Date

DRAWING REF: 3HS/BR/02



such as a change in level or material and to be min 250mm from front of closed appliance and 150mm from the side