

Hi Ben

I don't think anything has changed since my email of 25 June 2021 (attached)

They need to submit a full scheme demonstrating that the site will be protected from potential ground gas. Protection consistent with CS2 is suggested. This is quite straight forward and contains the following.

1. A statement to the effect that CS2 will sufficiently protect the site, given the risk presented
2. A description of appropriate CS2 measures with reference to appropriate literature.
3. A description of the measures to be adopted on site, demonstrating consistency with point 2 above. Utilising a gas protection score of 3.5 points, over at least 2 separate elements.

I can't see anything suitable on the portal!

Regards

Matthew Rhodes

Environmental Health Officer (Pollution Specialist)

High Peak Borough Council, Town Hall, Buxton, Derbyshire. SK17 6EL

Staffordshire Moorlands District Council, Moorlands House, Stockwell Street, Leek, Staffordshire.
ST13 6HQ

8 Website: www.highpeak.gov.uk www.staffsmoorlands.gov.uk


