
From: EHealth Consultation
Sent: 13 October 2022 15:39
To: Planning (HPBC)
Subject: HPK/2022/0427 Environmental Health Consultation#

Categories:

Dear Planning

Application number	HPK/2022/0427	Application type	Full - MINOR
Site address	Unit 3, Waterside Business Park, Waterside, Hadfield, Glossop, Derbyshire, SK13 1BE	Proposal	Proposed partial change of use of ground floor from general industrial (B2) to indoor sport, recreation or fitness (E(d)).

The Environmental Health Department has no objection to the proposed development subject to the conditions set out below being applied to any permission granted.

COMMENT:

The change of use at the site may give rise to issues of noise (from amplified music etc) to protect this amenity condition 1 is recommended.

CONDITION:

- 1) The door located on the eastern elevation of the building (adjacent to Waterside) shall be used for emergencies only and shall otherwise be kept closed. Sign to this effect shall be affixed to the inside of the door and maintained for the life of the development.

Environmental Health

High Peak Borough Council, Town Hall, Buxton, Derbyshire. SK17 6EL
Staffordshire Moorlands District Council, Moorlands House, Stockwell Street, Leek, Staffordshire. ST13 6HQ

Tel:

E-mail:

Website: www.highpeak.gov.uk www.staffsmoorlands.gov.uk



Do you really need to print out this Email? Be green - keep it on the screen.

This email is intended for the addressee(s) only and may contain sensitive, privileged or confidential information that could be protectively marked. If you are not the addressee please do not use the information in any way. If you have received this email in error please notify the sender immediately and delete it from your system. Thank you.

The Council may be required to disclose this email or any responses to it under the Freedom of Information Act 2000. The way in which we handle personal information is set out in our privacy notice and is available at <https://www.highpeak.gov.uk/YourData>
