

From: [Diane Clarke](#)
To: [Planning \(HPBC\)](#)
Subject: High Peak HPK-2022-0461 Chapel Rd agri workers dwelling-temp caravan
Date: 02 November 2022 13:49:45
Attachments: [Network Rail dev form Asset-Protection-Initial-Enquiry-Questionnaire.docx](#)

OFFICIAL

NEW APPLICATION	HPK/2022/0461
APPLICANT'S NAME	Ray And Jason Butler
LOCATION	Lower Cadster Farm Chapel Road Whaley Bridge
PROPOSED DEVELOPMENT	Application for a temporary agricultural workers dwelling including retrospective application for a temporary caravan
GRID REFERENCE	402322.38 379966.42

With reference to the protection of the railway, Network Rail has no objection in principle to the proposal, but below are requirements which MUST be met as the proposal includes works within 10m of the railway boundary and an interface with the railway boundary - therefore undertaking the works with the agreement and supervision of Network Rail is required. This is to ensure that the works on site, and as a permanent arrangement, do not impact upon the safe operation and integrity of the existing operational railway and for the avoidance of doubt of both the council and the developer who may not be aware of the potential for outside party proposals to impact upon the railway.

An interface with Network Rail is REQUIRED for this proposal. Please note that Network Rail may submit further comments on this proposal if required in addition to the comments below.

Network Rail recognises that conditions are imposed for a planning purpose and that they are fairly and reasonably related to the development and not be manifestly unreasonable. We believe that the comments included in this email are indeed fair and reasonable and relate to Network Rail's need to ameliorate the impacts that might otherwise flow from the development.

Measurements to railway tracks and railway boundary

When designing proposals, the developer and council are advised, that any measurements must be taken from the operational railway / Network Rail boundary and not from the railway tracks themselves. From the existing railway tracks to the Network Rail boundary, the land will include critical infrastructure (e.g. cables, signals, overhead lines, communication equipment etc) and boundary treatments (including support zones, vegetation) which might be adversely impacted by outside party proposals unless the necessary asset protection measures are undertaken. No proposal should increase Network Rail's liability. To ensure the safe operation and integrity of the railway, Network Rail issues advice on planning applications and **requests** conditions to protect the railway and its boundary.

Obligations

Properties adjoining or in the vicinity of the railway are frequently the subject of obligations, rights, exceptions and reservations for the benefit of Network Rail's land and railway. The applicant must review the title to their property to see whether any such obligations etc exist and ensure that there is no non-compliance or breaches of them or any interference with or obstruction of Network Rail's rights and reservations. If the proposed development would not comply with or would breach any of the terms of the conveyance, the developer must revise his proposals.

RAMS

The developer is to submit directly to Network Rail asset protection, a Risk Assessment and Method Statement (RAMS) for all works to be undertaken within 10m of the operational railway under Construction (Design and Management) Regulations, and this is in addition to any

planning consent. Network Rail would need to be re-assured the works on site follow safe methods of working and have also taken into consideration any potential impact on Network Rail land and the existing operational railway infrastructure. Builder to ensure that no dust or debris is allowed to contaminate Network Rail land as the outside party would be liable for any clean-up costs. Review and agreement of the RAMS will be undertaken between Network Rail and the applicant/developer.

Fencing

The applicant will provide at their own expense (if not already in place):

- A suitable trespass proof steel palisade fence of a minimum height of 1.8m adjacent to the boundary with the railway/railway land.
- The fence must be wholly constructed and maintained within the applicant's land ownership footprint.
- All foundations must be wholly constructed and maintained within the applicant's land ownership footprint without over-sailing or encroaching onto Network Rail's boundary.
- The fence is **REQUIRED** be set back at least 1m from the railway boundary to ensure that Network Rail can maintain and renew its boundary treatments.
- Existing Network Rail fencing, and boundary treatments, must not be damaged or removed in any way.
- Network Rail will not allow any maintenance works for proposal fencing or proposal boundary treatments to take place on its land.
- Proposal fencing must not be placed on the boundary with the railway.
- Any fencing over 1.8m in height will require agreement from Network Rail with details of foundations and wind loading calculations submitted for review.
- The fence should be maintained by the developer and that no responsibility is passed to Network Rail.

New residents of the development (particularly minors) may not be aware of the risks posed by accessing the railway. It would not be reasonable to require Network Rail to fund boundary works, fencing and boundary enhancements necessitated by outside party development adjacent to the railway.

Encroachment

The developer/applicant must ensure that their proposal, both during construction, and after completion of works on site, does not affect the safety, operation or integrity of the operational railway, Network Rail land and its infrastructure or undermine or damage or adversely affect any railway land and structures.

- There must be no physical encroachment of the proposal onto Network Rail land, no over-sailing into Network Rail air-space and no encroachment of foundations onto Network Rail land or under the Network Rail boundary.
- All buildings and structures on site including all foundations / fencing foundations must be constructed wholly within the applicant's land ownership footprint.
- Buildings and structures must not over-sail Network Rail air-space.
- Any future maintenance must be conducted solely within the applicant's land ownership.
- Rainwater goods must not discharge towards or over the railway boundary
- Should the applicant require access to Network Rail land to facilitate their proposal they would need to approach the Network Rail Asset Protection Team at least 20 weeks before any works are due to commence on site. The applicant would be liable for all costs incurred in facilitating the proposal and an asset protection agreement may be necessary to undertake works. Network Rail reserves the right to refuse any works by an outside party that may adversely impact its land and infrastructure.
- Any unauthorised access to Network Rail air-space or land will be deemed an act of trespass.

Drainage proposals and Network Rail land

The applicant must ensure that the proposal drainage does not increase Network Rail's liability, or cause flooding pollution or soil slippage, vegetation or boundary issues on railway land. Therefore, the proposed drainage on site will include the following:

- All surface waters and foul waters must drain away from the direction of the railway boundary.
- Soakaways for the proposal must be placed at least 30m from the railway boundary.
- Any drainage proposals for less than 30m from the railway boundary must ensure that surface and foul waters are carried from site in closed sealed pipe systems.
- Suitable drainage or other works must be provided and maintained by the developer to prevent surface water flows or run-off onto Network Rail's land and infrastructure.
- Proper provision must be made to accept and continue drainage discharging from Network Rail's property.
- Drainage works must not impact upon culverts, including culverts/brooks etc that drain under the railway. The applicant will not be permitted to direct surface or foul waters into culverts which run under the railway – any discharge of surface water under the railway via a culvert will require review and agreement from Network Rail who reserve the right to refuse use of any culverts.
- The developer must ensure that there is no surface or sub-surface flow of water towards the operational railway.
- Rainwater goods must not discharge in the direction of the railway or onto or over the railway boundary.
- Consideration of the impacts upon railway drainage of Astro-Turf/plastic lawn replacements, both during construction and any future inclusion of said Astro-turf by residents going forward.

NB: Soakaways can materially affect the strength of soil leading to stability issues. A large mass of water wetting the environment can soften the ground, and a build-up of water can lead to issues with the stability of Network Rail retaining walls/structures and the railway boundary. Network Rail does not accept the installation of soakaways behind any retaining structures as this significantly increases the risk of failure and subsequent risk to the travelling public.

Excavation and Earthworks and Network Rail land:

The applicant will agree all excavation and earthworks within 10m of the railway boundary with Network Rail. Network Rail will need to review and agree the works to determine if they impact upon the support zone of our land and infrastructure as well as determining relative levels in relation to the railway. Network Rail would need to agree the following:

- Alterations to ground levels
- De-watering works
- Ground stabilisation works
- Works to retaining walls
- Construction and temporary works
- Maintenance of retaining walls
- Ground investigation works must not be undertaken unless agreed with Network Rail.
- Confirmation of retaining wall works (either Network Rail and/or the applicant).
- Alterations in loading within 15m of the railway boundary must be agreed with Network Rail.
- For works next to a cutting or at the toe of an embankment the developer / applicant would be required to undertake a slope stability review.

Network Rail would need to review and agree the methods of construction works on site to ensure that there is no impact upon critical railway infrastructure. No excavation works are to commence without agreement from Network Rail. The council are advised that the impact of outside party excavation and earthworks can be different depending on the geography and soil in the area. The council and developer are also advised that support zones for railway infrastructure may extend beyond the railway boundary and into the proposal area. Therefore, consultation with Network Rail is requested. Any right of support must be maintained by the developer.

3m Gap

Network Rail **REQUIRES** that the developer includes a minimum 3 metres gap between the

buildings and structures on site and the railway boundary. Less than 3m from the railway boundary to the edge of structures could result in construction and future maintenance works being undertaken on Network Rail land, and close to the railway boundary potentially impacting support zones or lineside cabling. All the works undertaken to facilitate the design and layout of the proposal should be undertaken wholly within the applicant's land ownership footprint including all foundation works. Network Rail requires a minimum 3m easement between structures on site and the railway boundary to ensure that we can maintain and renew our boundary treatments. No part of the structure should over-sail the railway boundary or discharge rainwater goods onto or toward the railway boundary.

BAPA (Basic Asset Protection Agreement)

As the proposal includes works which could impact the existing operational railway and in order to facilitate the above, a **BAPA** (Basic Asset Protection Agreement) will need to be agreed between the developer and Network Rail. The developer will be liable for all costs incurred by Network Rail in facilitating this proposal, including any railway site safety costs, possession costs, asset protection costs / presence, site visits, review and agreement of proposal documents and any buried services searches. The BAPA will be in addition to any planning consent. The applicant / developer should liaise directly with Asset Protection to set up the BAPA (form attached).

AssetProtectionLNWNorth@networkrail.co.uk

No works are to commence until agreed with Network Rail. Early engagement with Network Rail is strongly recommended.

Should the above proposal be approved by the council and should there be conditions, where the proposal interfaces with the railway (as outlined in this response) the outside party is advised that a BAPA (Basic Asset Protection Agreement) must be in place, in order for Network Rail to review and agree the documentation and works outlined in conditions (and those areas covered by the discharge of conditions). Network Rail recommends that the applicant ensures that the BAPA is in place and that Network Rail has reviewed and agreed the documents as part of the discharge of any conditions.

From

Diane Clarke

Town Planning Technician NW&C

AssocRTPI

Network Rail

Email: TownPlanningLNW@networkrail.co.uk

The content of this email (and any attachment) is confidential. It may also be legally privileged or otherwise protected from disclosure.

This email should not be used by anyone who is not an original intended recipient, nor may it be copied or disclosed to anyone who is not an original intended recipient.

If you have received this email by mistake, please notify us by emailing the sender, and then delete the email and any copies from your system.

Liability cannot be accepted for statements made which are clearly the sender's own and not made on behalf of Network Rail.

Network Rail Infrastructure Limited registered in England and Wales No. 2904587, registered office Network Rail, 2nd Floor, One Eversholt Street, London, NW1 2DN.

