
From: Planning.APEast
Sent: 07 November 2022 11:13
To: Planning (HPBC)
Subject: HPK/2022/0433 - 7, Heath Grove, Buxton, Derbyshire, SK17 9EH CRM:0038841

Categories:

For the attention of Case Officer

Our Ref: P-221018-38028

Good Morning,

Re: Application No. HPK/2022/0433

Site Address : 7, Heath Grove, Buxton, Derbyshire, SK17 9EH

With reference to the above planning application the Company's observations regarding sewerage are as follows.

Planning Practice Guidance and section H of the Building Regulations 2010 detail surface water disposal hierarchy. The disposal of surface water by means of soakaways should be considered as the primary method. If this is not practical and there is no watercourse is available as an alternative other sustainable methods should also be explored. If these are found unsuitable, satisfactory evidence will need to be submitted, before a discharge to the public sewerage system is considered. No surface water to enter the foul water system by any means.

Please note for the use or reuse of sewer connections either direct or indirect to the public sewerage system the applicant will be required to make a formal application to the Company under Section 106 of the Water Industry Act 1991. They may obtain copies of our current guidance notes and application form from either our website (www.stwater.co.uk) or by contacting our Developer Services Team.

Suggested Informative

Severn Trent Water advises that there is a public sewer located within the application site. Public sewers have statutory protection by virtue of the Water Industry Act 1991 as amended by the Water Act 2003 and you may not build close to, directly over or divert a public sewer without consent. You are advised to contact Severn Trent Water to discuss your proposals. Severn Trent Water will seek to assist you in obtaining a solution which protects both the public sewer and the proposed development. They may obtain copies of our current guidance notes and application form from either our website (www.stwater.co.uk) or by contacting the Build Team.

Should you require any further information please contact us on email below.

Kind regards,

Asset Protection Team

Asset Protection
Asset Strategy and Planning
Chief Engineer
Severn Trent Water Ltd

Email:

Severn Trent Plc (registered number 2366619) and Severn Trent Water Limited (registered number 2366686) (together the "Companies") are both limited companies registered in England & Wales with their registered office at Severn Trent Centre, 2 St John's Street, Coventry, CV1 2LZ This email (which includes any files attached to it) is not contractually binding on its own, is intended solely for the named recipient and may contain CONFIDENTIAL, legally privileged or trade secret information protected by law. If you have received this message in error please delete it and notify us immediately by telephoning +44 2477715000. If you are not the intended recipient you must not use, disclose, distribute, reproduce, retransmit, retain or rely on any information contained in this email. Please note the Companies reserve the right to monitor email communications in accordance with applicable law and regulations. To the extent permitted by law, neither the Companies or any of their subsidiaries, nor any employee, director or officer thereof, accepts any liability whatsoever in relation to this email including liability arising from any external breach of security or confidentiality or for virus infection or for statements made by the sender as these are not necessarily made on behalf of the Companies. Reduce waste! Please consider the environment before printing this email