

Reference
NWGM232146

Date
22nd November 2022

Andrew Ryan
GEORGE MANSIONS,
THE SQUARE,
BUXTON,
SK17 6XW

Cadent Gas Limited
Pilot Way Ansty Park
Coventry CV7 9JU
United Kingdom
cadentgas.com



Dear Mr Ryan

Gas regulations require gas pipework runs up to the gas meter to be ventilated. With an existing building such as the George, these pipe runs cannot therefore be installed inside the building as they cannot be ventilated. The pipe runs therefore have to be installed on the exterior of the façade, which is how the building is currently served. The new proposed gas pipe routes on the facades are designed to be as inobtrusive as possible and are overall a reduction in the number of gas pipe runs which currently serve the building. The new gas pipe runs will be painted black to match the existing metalwork.

Yours sincerely

Damian Moss
MOBs Supervisor