

Please find attached document

Severn Trent Plc (registered number 2566619) and Severn Trent Water Limited (registered number 2566686) (together the "Company") are both limited companies registered in England & Wales with their registered office at Severn Trent Centre, 2 St John's Street, Coventry, CV1 2LZ. This email (which includes any files attached to it) is not contractually binding on its own, is intended solely for the named recipient and may contain CONFIDENTIAL, legally privileged or trade secret information protected by law. If you have received this message in error please delete it and notify us immediately by telephoning +44 2477715000. If you are not the intended recipient you must not use, disclose, distribute, reproduce, retransmit, rent or rely on any information contained in this email. Please note the Company reserves the right to monitor all communications in accordance with applicable law and regulations. To the extent permitted by law, neither the Company or any of its subsidiaries, nor any employee, director or officer shall accept liability or otherwise in relation to any information arising from any external breach of security or confidentiality or for virus infection or for statements made by the sender as these are not necessarily made on behalf of the Company. Reduce waste! Please consider the environment before printing this email

Unmapped sewers

Thank you for your consultation.

Having reviewed our statutory sewer records, they do not currently demonstrate any public sewers on the property. However, due to a change in Legislation that came into force October 2011, there could be unmapped assets on the property that will enjoy the same protection as all our mapped assets.

Protective strips:

100mm to 225mm diameter sewers – 3m either side of the pipe, thus providing 6m protection zone across the diameter of the pipe.

300mm to 999mm diameter sewers – 5m either side of the pipe and providing 10m protective strip, across the diameter of the pipe.

Any sewers greater than 999mm diameter, enjoy a protective strip of 7.5m either side of the pipe (15m across the diameter).

Further information about the transfer, along with guidance to determine whether they're served by a public sewer can be found on our website: <https://www.stwater.co.uk/my-supply/waste-water/looking-after-your-sewers/sewer-pipe-responsibility/>

If your client believes they're served by an unmapped public sewer, please advise them to contact us for further guidance on this matter (building.over@severntrent.co.uk – Tel: 0345 266 7930).

Regards

Dee Scott

Building Over Team

Network Solutions

Developer Services



For further information on building close to or over a public sewer, please follow the link below:

<https://www.stwater.co.uk/building-and-developing/house-developments/house-renovation/building-over-sewers/>

We have listened to our customers and local communities and Severn Trent have made a pledge to transform and protect the health of our Rivers, for more information please follow the link below:

<https://www.stwater.co.uk/get-river-positive/our-river-pledges/>

