
From: Planning.APEast <
Sent: 19 March 2023 20:47
To: Planning (HPBC)
Subject: HPK/2023/0069 - 60B Fairfield Road Buxton CRM:0038206

Categories:

For the attention of Case Officer

Our Ref: P-230222-39362

Good Afternoon,

Re Application: HPK/2023/0069
Re Site: 60B Fairfield Road Buxton

With reference to the above planning application the Company's observations regarding sewerage are as follows.

Planning Practice Guidance and section H of the Building Regulations 2010 detail surface water disposal hierarchy. The disposal of surface water by means of soakaways should be considered as the primary method. If this is not practical and there is no watercourse is available as an alternative other sustainable methods should also be explored. If these are found unsuitable, satisfactory evidence will need to be submitted, before a discharge to the public sewerage system is considered.

Please note for the use or reuse of sewer connections either direct or indirect to the public sewerage system the applicant will be required to make a formal application to the Company under Section 106 of the Water Industry Act 1991. They may obtain copies of our current guidance notes and application form from either our website (www.stwater.co.uk) or by contacting our Developer Services Team (Tel: 0800 707 6600).

Suggested Informative

Severn Trent Water advise that although our statutory sewer records do not show any public sewers within the area you have specified, there may be sewers that have been recently adopted under, The Transfer Of Sewer Regulations 2011. Public sewers have statutory protection and may not be built close to, directly over or be diverted without consent and you are advised to contact Severn Trent Water to discuss your proposals. Severn Trent will seek to assist you obtaining a solution which protects both the public sewer and the building.

This response only relates to the public waste water network and does not include representation from other areas of Severn Trent Water, such as the provision of water supply or the protection of drinking water quality.

Should you require any further information please contact us on email below.

Kind regards,

Asset Protection Team

Asset Protection Waste Water East
Asset Strategy and Planning
Chief Engineer
Severn Trent Water Ltd

Severn Trent Plc (registered number 2366619) and Severn Trent Water Limited (registered number 2366686) (together the "Companies") are both limited companies registered in England & Wales with their registered office at

Severn Trent Centre, 2 St John's Street, Coventry, CV1 2LZ This email (which includes any files attached to it) is not contractually binding on its own, is intended solely for the named recipient and may contain CONFIDENTIAL, legally privileged or trade secret information protected by law. If you have received this message in error please delete it and notify us immediately by telephoning +44 2477715000. If you are not the intended recipient you must not use, disclose, distribute, reproduce, retransmit, retain or rely on any information contained in this email. Please note the Companies reserve the right to monitor email communications in accordance with applicable law and regulations. To the extent permitted by law, neither the Companies or any of their subsidiaries, nor any employee, director or officer thereof, accepts any liability whatsoever in relation to this email including liability arising from any external breach of security or confidentiality or for virus infection or for statements made by the sender as these are not necessarily made on behalf of the Companies. Reduce waste! Please consider the environment before printing this email