

From: [EHealth Consultation](#)
To: [Planning \(HPBC\)](#)
Cc: [Hollins, Hannah](#)
Subject: DOC/2023/0027 Environmental Health Consultation#
Date: 16 May 2023 13:15:26

Dear Planning

Application number	DOC/2023/0027	Application type	Discharge of conditions
Site address	The Wrens Nest, Wren Nest Retail, Glossop Brook Road, Glossop, Derbyshire, SK13 8GN	Proposal	Discharge of condition 6 relating to HPK/2021/0651

Advice to LPA

The above application for discharge of condition 6 of HPK/2021/0651 has been forwarded to Environmental Health for consideration.

Consent	Condition	Requirement	Recommend for discharge*	Notes
HPK/2021/0651 (DOC/2023/0027)	6	Risk assessment approval	No	

*upon application

The information submitted in support of the application is insufficient to make a determination as to the discharge of the condition.

- CDM Partnership, "External Plant Details for Planning Consent" (ref: NG100 rev00) , dated March 2023

Condition 6 requires an assessment of the impact of noise (predicted noise) from heating and ventilation, upon the local amenity. This should be made in accordance with recognised guidance and standards (including BS4142 for instance).

Regards

Matthew Rhodes

Environmental Health Officer (Pollution Specialist)

High Peak Borough Council, Town Hall, Buxton, Derbyshire. SK17 6EL

Staffordshire Moorlands District Council, Moorlands House, Stockwell Street, Leek, Staffordshire. ST13 6HQ



8 Website: www.highpeak.gov.uk www.staffsmoorlands.gov.uk





