

From: Bower, Michele michele.bower@uuplc.co.uk
Subject: RE: Moorside , Old Glossop
Date: 30 Mar 2021 at 11:13:59
To: Phil p.ohagan227@btinternet.com

Good Morning Phil, hope you are well. I've been away from work on Jury Duty but back in now.

I have asked my colleagues on the Network for all scenarios to try and help you but as the new pump location is higher than our critical monitoring point (CMP) we cannot guarantee the pressure in the main. Our Network performance Engineer has supplied the info below..

no matter which main he takes his supply off there is no way we can guarantee water to his site with the pump where he wants it.

he wants to move the pump 15 metres higher than it currently is which means he will be reducing the inlet pressure by 15 MH.

If all the fields belong to him, could he not put the pump lower down? There is no way he can go without a pump/tank set.

I wouldn't recommend putting it above an elevation of 194 metres where we can guarantee minimum standards of service

I am sorry we cannot help any further with your query simply due to the height elevation.

Just as a matter of interest we are onsite after Easter to start laying mains on the new development below the stables. There may be a very slim small chance there is enough water from there but there are no guarantees

Kind Regards Michele

Michele Bower
Construction Engineer
Developer Services & Metering
M: [07768 175 271](tel:07768175271) (mobex 50981)
T: [0345 072 6067](tel:03450726067)
unitedutilities.com

Did you know we now have a live chat facility available to you Mon to Friday 8 -5pm. You just click on the orange live chat box on our webpage and one of our advisors will be ready to chat to you and help you with your enquiry <https://www.unitedutilities.com/builders-developers/> or you can email us at developerserviceswater@uuplc.co.uk

If you have received a great service today why not tell us?
Visit : <https://unitedutilities.thewowawards.co.uk/nominate>

-----Original Message-----

From: Phil [mailto:p.ohagan227@btinternet.com]
Sent: 30 March 2021 08:02
To: Bower, Michele <michele.bower@uuplc.co.uk>
Subject: Moorside , Old Glossop

Michelle

Good morning . Can you please let me know what is now being proposed so that I can start to plan the works during the spring and summer months . Please can you come back to me Regards Phil

EMGateway3.uuplc.co.uk made the following annotations

The information contained in this e-mail is intended only for the individual to whom it is addressed. It may contain legally privileged or confidential information or otherwise be exempt from disclosure. If you have received this Message in error or there are any problems, please notify the sender immediately and delete the message from your computer. You must not use, disclose, copy or alter this message for any unauthorised purpose. Neither United Utilities Group PLC nor any of its subsidiaries will be liable for any direct, special, indirect or consequential damages as a result of any virus being passed on, or arising from the alteration of the contents of this message by a third party.

United Utilities Group PLC, Haweswater House, Lingley Mere
Business Park, Lingley Green Avenue, Great Sankey,
Warrington, WA5 3LP
Registered in England and Wales. Registered No [6559020](#)

www.unitedutilities.com

www.unitedutilities.com/subsidiaries
