

From: [Stannard, James](#)
To: [Planning Comments \(HPBC\)](#)
Subject: HPK/2023/0055 - Further EH comments
Date: 20 June 2023 14:44:57

From: Rhodes, Matthew
Sent: Tuesday, June 20, 2023 2:41 PM
To: Stannard, James
Subject: RE: HPK/2023/0055 Environmental Health Consultation#

Hi James

It's a fair comment, and one that's been mulled over in acoustics circles for at least 20 years. The following will take into account low freq (bass) music noise

Sound (including music) attributable to any sound-amplifying equipment, loudspeaker, public address system etc. utilised within the premises, shall not exceed the following levels:

- a. 23:00 to 07:00 - Noise Rating Curve NR25, when measured in (or calculated for) the bedroom of any residential premises.
- b. 07:00 to 23:00 - Rating Curve NR35, when measured in (or calculated for) the living room of any residential premises.

Noise Rating Curves shall be measured as a 15 minute linear Leq at the octave band centre frequencies 31.5 Hz to 8 kHz

Matthew Rhodes
Environmental Health Officer (Pollution and Environment)

High Peak Borough Council, Town Hall, Buxton, Derbyshire. SK17 6EL
Staffordshire Moorlands District Council, Moorlands House, Stockwell Street, Leek, Staffordshire. ST13 6HQ

Mobile:

E-mail:

Website: www.highpeak.gov.uk

www.staffsmoorlands.gov.uk
