
From: Stannard, James
Sent: 13 July 2023 09:21
To: Planning Comments (HPBC)
Subject: DOC/2023/0040 - LLFA Comments

Categories:

Hi

Please see below comments from the Lead Local Flood Authority in connection with DOC/2023/0040

Regards

James Stannard MRTPI
Planning Officer
High Peak Borough Council and Staffordshire Moorlands District Council

From: Jo Crawshaw-Moore (Place)
Sent: Wednesday, July 12, 2023 3:24 PM
To: Stannard, James
Cc: Planning (HPBC)
Subject: RE: External Consultation Letter - App ref DOC/2023/0040

Good Afternoon James,

Thank you for consulting the Lead Local Flood Authority (LLFA) in relation to the above planning application. This replaces our previous response dated 23/06/2023.

We are unable to provide recommend that the conditions are discharged until the applicant has provided further information:

Condition 13

Regarding maintenance:

- Who will be responsible for maintaining the soakaway and the Downstream Defender?
- Please provide maintenance instructions for the soakaway.

Regarding the infiltration testing results in appendix F of the Technical Note:

- Paragraph 3.1 of the technical note states that infiltration rates between 6 and 2 m/hr were indicated by the testing. In the results for Trial Pit B, the time taken for test 3 to drain would lead to an infiltration rate of 0.075 m/hr. Please could this be clarified, ensuring that the lowest value is used in the modelling calculations.

As the site is within a Source Protection Zone, care must be taken regarding the quality of the water infiltrating via the permeable paving and soakaway. The proposed drainage design incorporates treatment for the surface water runoff, however, as the site is brownfield, is there any contamination in the ground that might be mobilised by the infiltrating water? The soakaway design in appendix D of the Technical Note and the modelling calculations indicate that water will infiltrate through the sides as well as the base of the soakaway and the base of the permeable paving would be well above the bedrock. The LPA would be advised to consult the Environment Agency regarding the suitability of the design of the infiltrating features and treatment from a water quality point of view.

Please clarify whether the perforated pipes within the permeable paving are perforated all the way round or at the top only. They should be perforated at the top only to avoid a concentration of infiltrating water close to buildings or the highway.

Please provide:

- Pipe sizes, materials, gradients and numbers and also site ground levels and finished floor levels on the Drainage Layout drawing in appendix C of the Technical Note
- A plan detailing the impermeable area attributed to each drainage asset
- A plan showing above ground flood pathways for events in excess of the 1% probability annual rainfall event, to ensure exceedance routes can be safely managed
- An indication of seasonal variations in ground water level to ensure that there is a minimum of 1m of unsaturated ground beneath infiltrating features

Please find attached a guide as to the requirements for modelling calculations.

Condition 14

This condition will be recommended for discharge at the same time as condition 13.

Condition 16

No information appears to have been provided regarding this condition.

Thank you.
Kind regards,
Jo

Jo Crawshaw-Moore | Senior Technician

Flood Risk Management

Place | Derbyshire County Council
County Hall, Matlock, Derbyshire, DE4 3AG

Visit us at www.derbyshire.gov.uk | Follow us on [Twitter](#) | Find us on [Facebook](#)

Join thousands of local residents who receive regular county council news direct to their inbox. Go to our [website](#) and click on the Sign Up button.

Think before you print! Save energy and paper. Do you really need to print this email?

Derbyshire County Council works to improve the lives of local people by delivering high quality services. You can find out more about us by visiting www.derbyshire.gov.uk.

If you want to work for us go to our job pages on www.derbyshire.gov.uk/jobs. You can register for e-mail alerts, download job packs and apply on-line.

Please Note

This email is confidential, may be legally privileged and may contain personal views that are not the views of Derbyshire County Council. It is intended solely for the addressee. If this email was sent to you in error please notify us by replying to the email. Once you have done this please delete the email and do not disclose, copy, distribute, or rely on it.

Under the Data Protection Act 2018 and the Freedom of Information Act 2000 the contents of this email may be disclosed.

Any personal information you have given us will be processed in accordance with our privacy notices, available at www.derbyshire.gov.uk/privacynotices.

Derbyshire County Council reserves the right to monitor both sent and received emails.

CONTROLLED

Do you really need to print out this Email? Be green - keep it on the screen.

This email is intended for the addressee(s) only and may contain sensitive, privileged or confidential information that could be protectively marked. If you are not the addressee please do not use the information in any way. If you have received this email in error please notify the sender immediately and delete it from your system. Thank you.

The Council may be required to disclose this email or any responses to it under the Freedom of Information Act 2000. The way in which we handle personal information is set out in our privacy notice and is available at <https://www.highpeak.gov.uk/YourData>
