

From: [EHealth Consultation](#)
To: [Hollins, Hannah](#)
Cc: [Planning \(HPBC\)](#)
Subject: RE: DOC/2023/0027 Environmental Health Consultation#
Date: 02 August 2023 16:21:07

Hi Hannah

The report does not assess the potential noise at Wren Nest Mill apartments. The consultant has had a look at the map, and not realised the mill has residential premises. The report should be updated to include an assessment of noise at these critical noise sensitive receptors.

- Acoustic Associates SW Ltd, "Environmental Noise Assessment" (ref: 7868 rev0), dated 22 June 2023

Regards

Matthew Rhodes

Environmental Health Officer (Pollution and Environment)

High Peak Borough Council, Town Hall, Buxton, Derbyshire. SK17 6EL

Staffordshire Moorlands District Council, Moorlands House, Stockwell Street, Leek, Staffordshire. ST13 6HQ

Mobile:

E-mail:

Website: www.highpeak.gov.uk www.staffsmoorlands.gov.uk



From: Hollins, Hannah
Sent: Friday, June 23, 2023 2:35 PM
To: EHealth Consultation
Subject: FW: DOC/2023/0027 Environmental Health Consultation#

Good afternoon,

Since your previous comments on the information submitted for DOC/2023/0027 at The Wrens Nest, Wren Nest Retail Glossop Brook Road, Glossop, I have received the requested outstanding information from the agent, which I have forwarded to you.

Your further feedback would be greatly appreciated.

Kind regards,

Hannah Hollins

Trainee Planning Officer

Staffordshire Moorlands District Council and High Peak Borough Council

Tel:

Mobile:

From: Sarah Carpenter
Sent: Friday, June 23, 2023 12:51 PM
To: Hollins, Hannah
Subject: RE: DOC/2023/0027 Environmental Health Consultation#

Afternoon Hannah

Hope you have survived the week.

Please find attached the noise report, which has highlighted additional silencers, which have been incorporated into the design.

If you have any further queries, please do not hesitate to contact.

Have a good weekend.

Kind regards,

Sarah Carpenter BA(Hons) DipTP

Planware Ltd

St Andrews Castle
33 St Andrews Street South
Bury St Edmunds
IP33 3PH

Tel:

Mob:

From: Hollins, Hannah

Sent: Monday, May 22, 2023 8:50 AM

To: Sarah Carpenter

Subject: FW: DOC/2023/0027 Environmental Health Consultation#

Good morning Sarah,

I have now received some feedback from Environmental Health regarding condition 6, which I have forwarded to you. As soon as you are able to submit the requested details, I will reconsult Environmental Health and hopefully we can discharge the condition at this point.

Kind regards,

Hannah Hollins

Trainee Planning Officer

Staffordshire Moorlands District Council and High Peak Borough Council

Tel:

From: EHealth Consultation

Sent: Tuesday, May 16, 2023 1:15 PM

To: Planning (HPBC)

Cc: Hollins, Hannah

Subject: DOC/2023/0027 Environmental Health Consultation#

Dear Planning

Application number	DOC/2023/0027	Application type	Discharge of conditions
Site address	The Wrens Nest, Wren Nest Retail, Glossop Brook Road, Glossop, Derbyshire, SK13 8GN	Proposal	Discharge of condition 6 relating to HPK/2021/0651

Advice to LPA

The above application for discharge of condition 6 of HPK/2021/0651 has been forwarded to Environmental Health for consideration.

Consent	Condition	Requirement	Recommend for discharge*	Notes
HPK/2021/0651 (DOC/2023/0027)	6	Risk assessment approval	No	

*upon application

The information submitted in support of the application is insufficient to make a determination as to the discharge of the condition.

- CDM Partnership, "External Plant Details for Planning Consent" (ref: NG100 rev00) , dated March 2023

Condition 6 requires an assessment of the impact of noise (predicted noise) from heating and ventilation, upon the local amenity. This should be made in accordance with recognised guidance and standards (including BS4142 for instance).

Regards

Matthew Rhodes
Environmental Health Officer (Pollution Specialist)
High Peak Borough Council, Town Hall, Buxton, Derbyshire. SK17 6EL
Staffordshire Moorlands District Council, Moorlands House, Stockwell Street, Leek, Staffordshire. ST13 6HQ
8 Website: www.highpeak.gov.uk www.staffsmoorlands.gov.uk



Do you really need to print out this Email? Be green - keep it on the screen.

This email is intended for the addressee(s) only and may contain sensitive, privileged or confidential information that could be protectively marked. If you are not the addressee please do not use the information in any way. If you have received this email in error please notify the sender immediately and delete it from your system. Thank you.

The Council may be required to disclose this email or any responses to it under the Freedom of Information Act 2000. The way in which we handle personal information is set out in our privacy notice and is available at <https://www.highpeak.gov.uk/YourData>

Do you really need to print out this Email? Be green - keep it on the screen.

This email is intended for the addressee(s) only and may contain sensitive, privileged or confidential information that could be protectively marked. If you are not the addressee please do not use the information in any way. If you have received this email in error please notify the sender immediately and delete it from your system. Thank you.

The Council may be required to disclose this email or any responses to it under the Freedom of Information Act 2000. The way in which we handle personal information is set out in our privacy notice and is available at <https://www.highpeak.gov.uk/YourData>

Do you really need to print out this Email? Be green - keep it on the screen.

This email is intended for the addressee(s) only and may contain sensitive, privileged or confidential information that could be protectively marked. If you are not the addressee please do not use the information in any way. If you have received this email in error please notify the sender immediately and delete it from your system. Thank you.

The Council may be required to disclose this email or any responses to it under the Freedom of Information Act 2000. The way in which we handle personal information is set out in our privacy notice and is available at <https://www.highpeak.gov.uk/YourData>

Do you really need to print out this Email? Be green - keep it on the screen.

This email is intended for the addressee(s) only and may contain sensitive, privileged or confidential information that could be protectively marked. If you are not the addressee please do not use the information in any way. If you have received this email in error please notify the sender immediately and delete it from your system. Thank you.

The Council may be required to disclose this email or any responses to it under the Freedom of Information Act 2000. The way in which we handle personal information is set out in our privacy notice and is available at <https://www.highpeak.gov.uk/YourData>
