
From: Rhodes, Matthew
Sent: 10 November 2023 14:13
To: Planning Comments (HPBC)
Cc: Stannard, James
Subject: HPK/2023/0416 - Environmental Health Consultation#

Categories:

Dear James

Application number	HPK/2023/0416	Application type	Full - MINOR
Site address	Land Opposite 2, Chapel Brow, Charlesworth, Derbyshire,	Proposal	Construction of a new 3 storey, 4 bedroom detached dwelling with associated landscaping and car parking on the land rear of 44/46 Town Lane, Charlesworth, fronting access from Chapel Brow.

COMMENTS:

The Environmental Health Department has no objection to the proposed development subject to the conditions set out below being applied to any permission granted.

Sensitive Use

The proposed end use of the development is particularly sensitive to the presence of land contamination, for this reason the following conditions 1 is recommended.

Construction

The construction/demolition stage of the development could lead to an increase of noise and dust etc. experienced at sensitive premises and subsequent loss of amenity, for this reason conditions 2 to 7 are suggested.

CONDITIONS:

1. CL05 CONTAMINATED LAND – IF FOUND DURING DEVELOPMENT

If during development any contamination or evidence of likely contamination is identified that has not previously been identified or considered, then the applicant shall submit a written scheme to identify and control that contamination. This shall include a phased risk assessment carried out in accordance with the procedural guidance of the Environmental Protection Act 1990 Part IIA, and appropriate remediation proposals, and shall be submitted to the Local Planning Authority without delay. The approved remediation scheme shall be implemented to the satisfaction of the Local Planning Authority.

2. CDD01B - CONSTRUCTION AND DEMOLITION – DUST

No activity hereby permitted shall cause dust to be emitted beyond the site boundary so as to adversely adjacent residential properties and/or other sensitive uses and/or the local environment. In the event dust is caused to escape the site boundary the activity shall be stopped until sufficient dust suppression has been undertaken to prevent further escape. There shall always be the appropriate means and sufficient water resources on site for dust suppression. These should be made available for inspection when required by officers of the Local Planning Authority

3. CDD02 - CONSTRUCTION & DEMOLITION: WASTE DISPOSAL

Any waste material associated with the demolition or construction shall not be burnt on site but shall be kept securely for removal to prevent escape into the environment.

There shall be no fires lit on the site for purpose of disposing of demolition materials. Any open fires that arise shall be extinguished without delay.

4. NSD12 - BEST PRACTICAL MEANS

The best practicable means, as defined in Section 72 of the Control of Pollution Act 1974 to reduce noise and vibration from the site to a minimum, shall be employed at all times during construction.

5. NSD02B - NOISE CONSTRUCTION: PILING 2

If piling is necessary, a written piling options assessment shall be submitted to the Local Planning Authority, to demonstrate noise and vibration mitigation measures consistent with best practical means.

The assessment shall consider Environment Agency guidance (*Environment Agency (2001), Piling and Penetrative Ground Improvements on Land Affected by Land Contamination NC/99/73*) where land contamination is suspected or proven. No piling shall take place until the piling options assessment has been approved.

No piling shall take place outside the hours 09:00 hours to 16:00 hours Mondays to Fridays.

6. NS02A - CONSTRUCTION & DEMOLITION WORKS: TIME OF OPERATIONS

Unless prior permission has been obtained in writing from the Local Planning Authority, all noise-generating activities shall be restricted to the following times of operations.

- 07:30 - 18:00 hours (Monday to Friday);
- 08:30 - 14:00 hours (Saturday)
- No working is permitted on Sundays or Bank Holidays.

In this condition, a noise-generating activity is defined as any activity (for instance, but not restricted to, building construction/demolition operations, refurbishing and landscaping) which generates noise that is audible at the site boundary.

7. CDD14 - ON SITE RADIO

During construction/demolition phases amplified music and/or radios shall not be audible beyond the site boundary.

Regards

Matthew Rhodes
Environmental Health Officer (Pollution and Environment)

High Peak Borough Council and Staffordshire Moorlands District
Council Mobile:

www.highpeak.gov.uk | Follow HPBC on [Twitter](#) | [Facebook](#)

www.staffsmoorlands.gov.uk | Follow SMDC on [Twitter](#) | [Facebook](#)



Do you really need to print out this Email? Be green - keep it on the screen.

This email is intended for the addressee(s) only and may contain sensitive, privileged or confidential information that could be protectively marked. If you are not the addressee please do not use the information in any way. If you have received this email in error please notify the sender immediately and delete it from your system. Thank you.

The Council may be required to disclose this email or any responses to it under the Freedom of Information Act 2000. The way in which we handle personal information is set out in our privacy notice and is available at <https://www.highpeak.gov.uk/YourData>
