
From: Rhodes, Matthew
Sent: 14 November 2023 14:43
To: Planning Comments (HPBC)
Cc: Robinson, Rachel
Subject: HPK/2023/0322 - Environmental Health Consultation#

Categories:

Hi Rachel

Application number	HPK/2023/0322	Application type	Full - Householder
Site address	Eversleigh, Stubbins Lane, Chinley, Derbyshire, SK23 6EB	Proposal	Installation of Air Source Heat Pump to replace old gas boiler

ASHP are permitted development, unless (amongst other things) they fail to comply with the Microgeneration Certification Scheme Planning Standards (MCS 020). So a copy of the MCS 020 assessment should be included with the application, along with any other factors that preclude its PD status.

In the absence of this the application should be refused unless a full BS 4142 assessment of noise is included at application stage.

Regards

Matthew Rhodes
Environmental Health Officer (Pollution and Environment)

High Peak Borough Council and Staffordshire Moorlands District Council

Mobile:

www.highpeak.gov.uk | Follow HPBC on [Twitter](#) | [Facebook](#)

www.staffsmoorlands.gov.uk | Follow SMDC on [Twitter](#) | [Facebook](#)



Do you really need to print out this Email? Be green - keep it on the screen.

This email is intended for the addressee(s) only and may contain sensitive, privileged or confidential information that could be protectively marked. If you are not the addressee please do not use the information in any way. If you have received this email in error please notify the sender immediately and delete it from your system. Thank you.

The Council may be required to disclose this email or any responses to it under the Freedom of Information Act 2000. The way in which we handle personal information is set out in our privacy notice and is available at <https://www.highpeak.gov.uk/YourData>
