
From: Adrian Martin (Place) <>

Sent: Wednesday, January 3, 2024 9:20 AM

To: Simpkin, Rachael. <>

Subject: DOC/2023/0087 - Land at Foxlow Farm, Harpur Hill Road, Buxton.

Dear Rachel,

I refer to the above application received by this authority for highway comments. It is unlikely that the highway authority would raise objections to the discharge of condition 29 as applied for; however, there are no details available of the luminance of the proposed lighting. If the luminance does not exceed 800 cd/m², in accordance with the recommended guidance, there would be no objections to the application. Should consent be granted for the application, it is recommended that the following condition is included in that consent:

1. The proposed lighting shall have a luminosity not exceeding 800 candelas per square metre.

Yours sincerely,

Adrian Martin

Adrian Martin MCIHT | Project Engineer | Highways Development Control | Place | Derbyshire County Council | direct dial: |

Visit us at www.derbyshire.gov.uk | Follow us on Twitter | Find us on Facebook

We are now charging for our transport pre application advice service, for more details on our pre application advice and other Highway guidance, please see Derbyshire County Council website by following the link below.

[Transport Development Management Advice](#)

The cold weather can cause problems for older and more vulnerable people. Get advice and support on how to **Stay Well This Winter**. Find out more on [our website here](#).
