

**Subject:** FW: 2022.019 Dinting Vale HPK/2022/0456 - LLFA

-----Original Message-----

From: Jo Crawshaw-Moore (Place)

Sent: Wednesday, June 28, 2023 1:16 PM

To: Steven Gunn-Russell

Subject: RE: Rev Plans General External Consultation 21 Days - App ref HPK/2022/0456

Good Afternoon Steven,

Thank you for providing the revised information to the Lead Local Flood Authority (LLFA) in relation to the above planning application.

The LLFA notes the alterations to the proposed drainage strategy, however, there remain some clarifications before we can provide our final response:

- What are the functions of the proposed swale, attenuation ponds and tree pits and how are they connected to the drainage scheme?
- What area is the discharge rate based on?
- An indication of the proposed impermeable area
- The discharge rate for Network 3 should be restricted to as near to the greenfield rate as possible, or a minimum of 2 l/s.
- Evidence of permission for the 2 discharge points into the watercourse within third party land (Networks 1 & 3)

Thank you.

Kind regards,

Jo

Jo Crawshaw-Moore | Senior Technician  
Flood Risk Management

Place | Derbyshire County Council

County Hall, Matlock, Derbyshire, DE4 3AG T 01629 538584 M 07812 473016 E jo.crawshaw-moore@derbyshire.gov.uk

Visit us at [www.derbyshire.gov.uk](http://www.derbyshire.gov.uk) | Follow us on Twitter | Find us on Facebook