

From: [James Stannard](#)
To: [Planning Comments \(HPBC\)](#)
Subject: HPK/2024/0073 - ATM replacement, Rubicon House, Market Place, Chapel en le Frith.
Date: 03 April 2024 09:45:16

Please see below comments from Derbyshire Police in connection with HPK/2024/0073

James Stannard Planning Officer
Development Services
High Peak Borough Council and Staffordshire Moorlands District Council
Tel: **07976 753958**
www.highpeak.gov.uk | Follow HPBC on [Twitter](#) | [Facebook](#)
www.staffsmoorlands.gov.uk | Follow SMDC on [Twitter](#) | [Facebook](#)

Please note that my working days are Monday-Thursday

From: Beswick, Keith, 17000
Sent: Tuesday, April 2, 2024 7:35 PM
To: Planning (HPBC)
Cc: James Stannard
Subject: Response to consultation for application HPK/2024/0073 - ATM replacement, Rubicon House, Market Place, Chapel en le Frith.

Hello James,

Thank you for referring this application for our consideration.

The current ATM installation has not historically presented great crime problems according to recorded data.

The location is reasonable open, and approaches well lit by road lighting columns. Consequently, as a direct replacement for an existing provision, there would be no reason to object to this application as a matter of principle.

In respect of the detail, I would recommend that the illumination of the immediate ATM area frontage is given further consideration to what appears within the supporting information.

The issue of illumination is explored, but this relates more to the legibility of the ATM screen and surrounds, as opposed to ambient illumination for the reassurance of legitimate users, and identification of those committing crimes at the ATM face, such as the fraudulent use of cards and fitting of card skimming or retention devices. The output of 150 candelas per square metre is a standard feature (potentially higher) for external LED screen legibility.

To assist with the prevention and detection of crime, and to provide sufficient illumination to accompany the CCTV camera mounted to the side of the ATM face, I'd ask that the installation should follow the ATM industry's own Security Working Group guidance of a minimum 50 lux illumination

up to 1 metre from the ATM face and 75cm either side if the ATM central point.

There is an existing floodlight mounted directly above the ATM, which on face value would provide far too intense an output for the application, and possibly because of this, is not operating at present.

The replacement of the ATM would give an opportunity to replace this floodlight with a more appropriate provision, probably a flush mounted and vandal resistant bulkhead unit, with operating capacity matching that mentioned above.

Regards

Keith Beswick Ad Cert ED&CP, LCGI
Force Designing Out Crime Officer
Prevention and Partnerships Team

Derbyshire Constabulary Headquarters
Butterley Hall, Ripley, Derbyshire, DE5 3RS

Web: <http://www.derbyshire.police.uk>



PLEASE NOTE: This e-mail message is intended solely for the person to whom it is addressed and may contain information of a confidential or legally privileged nature which should not be disclosed. If you have received this message in error, please notify the sender immediately and delete the message and any attachments or copies. Any review, re-transmission, dissemination or other use of, or taking action in reliance upon, this message by persons or entities other than the intended recipient is prohibited. Any views or opinions expressed in this e-mail are solely those of the author and do not necessarily represent the views of Derbyshire Constabulary or any other person and Derbyshire Constabulary does not accept liability for any statement or opinion expressed. Please be aware Derbyshire Constabulary monitors all internet e-mail activity and content to maintain system performance and appropriate business usage. Derbyshire Constabulary's privacy notice can be viewed [Here](#).

Do you really need to print out this Email? Be green - keep it on the screen.

This email is intended for the addressee(s) only and may contain sensitive, privileged or confidential information that could be protectively marked. If you are not the addressee please do not use the information in any way. If you have received this email in error please notify the sender immediately and delete it from your system. Thank you.

The Council may be required to disclose this email or any responses to it under the Freedom of Information Act 2000. The way in which we handle personal information is set out in our privacy notice and is available at <https://www.highpeak.gov.uk/YourData>
