

The Planning Inspectorate

COMMENTS ON CASE (Online Version)

Please note that comments about this case need to be made within the timetable. This can be found in the notification letter sent by the local planning authority or the start date letter. Comments submitted after the deadline may be considered invalid and returned to sender.

Appeal Reference: APP/H1033/W/24/3341260

DETAILS OF THE CASE

Appeal Reference APP/H1033/W/24/3341260

Appeal By TREVILLE PROPERTIES LTD

Site Address
Land to the west of Bridgemont
Whaley Bridge
SK23 7GW
Grid Ref Easting: 401209
Grid Ref Northing: 382381

SENDER DETAILS

Name MRS LISA SELBY

Address
AES
Unit 9 Waterswallows Industrial Park
BUXTON
SK17 7JB

Company/Group/Organisation Name Alliance Environmental Services Ltd

ABOUT YOUR COMMENTS

In what capacity do you wish to make representations on this case?

- ☐ Appellant
- ☐ Agent
- ☒ Interested Party / Person
- ☐ Land Owner
- ☐ Rule 6 (6)

What kind of representation are you making?

- ☐ Final Comments
- ☐ Proof of Evidence
- ☐ Statement
- ☐ Statement of Common Ground
- ☒ Interested Party/Person Correspondence

☐ Other

YOUR COMMENTS ON THE CASE

Properties should be planned so bins can be stored within the property boundary and be moved to the presentation point without the need to go up or down steps or through the property. Garden gates need to be wide enough to accommodate a standard 240l wheeled bin.

Collection vehicles are unable to access unadopted highway unless an indemnity form has been completed by the developer. In instances where there is no indemnity for properties will have to present their bins at a point next to the nearest adopted highway.

All roads that are intended to be used for the purposes of waste collection must be suitable for a full size 32 tonne waste collection vehicle with a turning circle of 22.5m. It is advisable to design out the need for collection vehicles to reverse where possible. If reversing is unavoidable the following must be applied:

- waste collection vehicles should not reverse more than 12 meters
- the reverse should be straight and free from obstacles and visual obstructions. Please provide a tracked plan to show waste collection vehicle access and turning and indicate waste collection points for each property on the plan.

Please provide as part of the planning application a tracked plan to show waste collection vehicle access and turning.