

From: [Matthew Rhodes](#)
To: [Planning Comments \(HPBC\)](#)
Cc: ["Declan Cleary"](#)
Subject: HPK/2024/0141 - Environmental Health Consultation#
Date: 11 September 2024 16:25:08

Hi Declan

Application number	HPK/2024/0141	Application type	Full - MINOR
Site address	Railway Stables, Surrey Street, Glossop, Derbyshire, SK13 7AJ	Proposal	New Storage Workshop unit for use ancillary to existing industrial processes on site.

COMMENTS:

The Environmental Health Department has no objection to the proposed development subject to the conditions set out below being applied to any permission granted.

Sensitive Use

The proposed end use of the development is particularly sensitive to the presence of land contamination, for this reason the following conditions 1 is recommended.

Noise

Conditions 2 and 3 are suggested to protect local amenity.

Construction

The construction/demolition stage of the development could lead to an increase of noise and dust etc. experienced at sensitive premises and subsequent loss of amenity, for this reason conditions 4to 9 are suggested.

INF12 – DEMOLITION/REFURBISHMENT: ASBESTOS INFORMATIVE

A Demolition or refurbishment asbestos survey and risk assessment should be carried out prior to the demolition/renovation of the existing buildings. The enforcing authority for this type of work is the Health and Safety Executive (HSE) and it is recommended that you contact them directly to discuss their requirements: <http://www.hse.gov.uk/>

CONDITIONS:

1. CL05 CONTAMINATED LAND – IF FOUND DURING DEVELOPMENT

If during development any contamination or evidence of likely contamination is identified that has not previously been identified or considered, then the applicant shall submit a written scheme to identify and control that contamination. This shall include a phased risk assessment carried out in accordance with the procedural guidance of the Environmental Protection Act 1990 Part IIA, and appropriate remediation proposals, and shall be submitted to the Local Planning Authority without delay. The approved remediation scheme shall be implemented to the satisfaction of the Local Planning Authority.

2. NS07 - NOISE RATING LEVEL: INDUSTRIAL PREMISES

The maximum rated noise level emitted from the development shall not exceed the following levels when measured 1 meter from the façade of any residential premises (where that façade has a window or door opening).

- a. 50dB LAeq (1 hr) (freefield) for any period of one hour between 07:00 – 23:00hrs
- b. 45dB LAeq (15 minutes) (freefield) for any period of 15 minutes between 23:00 and 07:00

All measurements, calculations and corrections shall be made in accordance with the methodology of BS 4142:2014+A1:2019 "*Methods for rating and assessing industrial and commercial sound*" and/or its subsequent amendments.

Where access to the nearest sound sensitive property is not possible, measurements shall be undertaken at an appropriate location and a distance correction applied.

3. WHITE NOISE REVERSING ALARMS

Any forklift truck, or other vehicle routinely used on site for loading or unloading materials or product, shall operate on site with white noise reversing alarms only.

4. CDD01B - CONSTRUCTION AND DEMOLITION – DUST

No activity hereby permitted shall cause dust to be emitted beyond the site boundary so as to adversely adjacent residential properties and/or other sensitive uses and/or the local environment. In the event dust is caused to escape the site boundary the activity shall be stopped until sufficient dust suppression has been undertaken to prevent further escape. There shall always be the appropriate means and sufficient water resources on site for dust suppression. These should be made available for inspection when required by officers of the Local Planning Authority.

5. CDD02 - CONSTRUCTION & DEMOLITION: WASTE DISPOSAL

Any waste material associated with the demolition or construction shall not be burnt on site but shall be kept securely for removal to prevent escape into the environment. There shall be no fires lit on the site for purpose of disposing of demolition materials. Any open fires that arise shall be extinguished without delay.

6. NSD12 - BEST PRACTICAL MEANS

The best practicable means, as defined in Section 72 of the Control of Pollution Act 1974 to reduce noise and vibration from the site to a minimum, shall be employed at all times during construction.

7. NSD02B - NOISE CONSTRUCTION: PILING 2

If piling is necessary, a written piling options assessment shall be submitted to the Local Planning Authority, to demonstrate noise and vibration mitigation measures consistent with best practical means.

The assessment shall consider Environment Agency guidance (*Environment Agency (2001), Piling and Penetrative Ground Improvements on Land Affected by Land Contamination NC/99/73*) where land contamination is suspected or proven. No piling shall take place until the piling options assessment has been approved.

No piling shall take place outside the hours 09:00 hours to 16:00 hours Mondays to Fridays.

8. NS02A - CONSTRUCTION & DEMOLITION WORKS: TIME OF OPERATIONS

Unless prior permission has been obtained in writing from the Local Planning Authority, all noise-generating activities shall be restricted to the following times of operations.

- 07:30 - 18:00 hours (Monday to Friday);
- 08:30 - 14:00 hours (Saturday)
- No working is permitted on Sundays or Bank Holidays.

In this condition, a noise-generating activity is defined as any activity (for instance, but not restricted to, building construction/demolition operations, refurbishing and landscaping) which generates noise that is audible at the site boundary.

9. CDD14 - ON SITE RADIO

During construction/demolition phases amplified music and/or radios shall not be audible beyond the site boundary.

Regards

Matthew Rhodes
Environmental Health Officer (Pollution and Environment)

High Peak Borough Council and Staffordshire Moorlands District Council
www.highpeak.gov.uk | Follow HPBC on [Twitter](#) | [Facebook](#)
www.staffsmoorlands.gov.uk | Follow SMDC on [Twitter](#) | [Facebook](#)



Do you really need to print out this Email? Be green - keep it on the screen.

This email is intended for the addressee(s) only and may contain sensitive, privileged or confidential information that could be protectively marked. If you are not the addressee please do not use the information in any way. If you have received this email in error please notify the sender immediately and delete it from your system. Thank you.

The Council may be required to disclose this email or any responses to it under the Freedom of Information Act 2000. The way in which we handle personal information is set out in our privacy notice and is available at <https://www.highpeak.gov.uk/YourData>
