

---

Application Reference No. : HPK/2024/0360

Site Address: 21 PEAK PHARMACY High Street Chapel-En-Le-Frith Derbyshire SK23 0HQ HIGH PEAK

Comments by: Ms Lisa SelbyAlliance Environmental Services Ltd

From:

AES

Unit 9 Waterswallows Industrial Park

Buxton

BUXTON

West Midlands

SK17 7JB

Submission: Objection

Comments: There is not enough storage space in the yard to the rear of the property for the correct capacity of refuse and recycling. Each of the rooms within the HMO should be provided with 240 litres for recycling and 240 litres for refuse, there is also a requirement from 2026 for these properties to be provided with a weekly food waste collection, which will also require suitable receptacle storage space.

---

Do you really need to print out this Email? Be green - keep it on the screen.

This email is intended for the addressee(s) only and may contain sensitive, privileged or confidential information that could be protectively marked. If you are not the addressee please do not use the information in any way. If you have received this email in error please notify the sender immediately and delete it from your system. Thank you.

The Council may be required to disclose this email or any responses to it under the Freedom of Information Act 2000. The way in which we handle personal information is set out in our privacy notice and is available at <https://www.highpeak.gov.uk/YourData>

---