

Planning Department
High Peak Borough Council
Development Control
Municipal Buildings Market Place
Glossop
Derbyshire
SK13 8AF

Our ref: LT/2024/128560/03-L01
Your ref: DOC/2024/0047
Date: 08 October 2024

Dear Sir/Madam

**DISCHARGE OF CONDITIONS 2, 3, 4, 5, 6, 7, 10, 11, 15, 16, 18 AND 20 RELATING
TO HPK/2021/0216
FORGE WORKS FORGE ROAD CHINLEY**

Thank you for consulting the Environment Agency on the above application.

Environment Agency Position

Further to the submission of access bridge design details) in relation to the discharge of Condition 11 on the approved planning permission for the site.

We would have **no objection** to the construction of a proposed single span bridge with a confirmed minimum soffit height constructed at the modelled 100-year flood level, plus allowance for climate change (CC) and 0.6m additional 'freeboard' contingency (for debris blockages) - as shown.

We request a copy of the decision notice once this case has been decided.

Yours faithfully

Ms Huda Al Tahhan
Planning Advisor