

**Subject:** FW: HPK/2024/0289 - Environmental Health Consultation#  
**Date:** 30 October 2024 15:56:06

Please see comments from Env Health in connection with HPK/2024/0289

**James Stannard** Planning Officer  
Development Services  
High Peak Borough Council and Staffordshire Moorlands District Council  
[www.highpeak.gov.uk](http://www.highpeak.gov.uk) | Follow HPBC on [Twitter](#) | [Facebook](#)  
[www.staffsmoorlands.gov.uk](http://www.staffsmoorlands.gov.uk) | Follow SMDC on [Twitter](#) | [Facebook](#)

**Please note that my working days are Monday-Thursday**

**From:** Matthew Rhodes  
**Sent:** 29 October 2024 16:48  
**To:** Planning (HPBC)  
**Cc:** James Stannard  
**Subject:** HPK/2024/0289 - Environmental Health Consultation#

Dear Planning

|                           |                                                                |                         |                                        |
|---------------------------|----------------------------------------------------------------|-------------------------|----------------------------------------|
| <b>Application number</b> | HPK/2024/0289                                                  | <b>Application type</b> | Full Planning - Small-scale MAJOR apps |
| <b>Site address</b>       | Football Ground , Silverlands , Buxton , Derbyshire , SK17 6QH | <b>Proposal</b>         | Erection of replacement stand          |

**ADVICE TO LPA:**  
The Environmental Health Department has no objection to the proposed development subject to the conditions set out below being applied to any permission granted.

**CONDITIONS:**

**LGD01 – Sports Lighting**  
Prior to any exterior lighting or floodlighting associated with the development being brought into use, a report shall be submitted and approved in writing by the LPA, demonstrating compliance with BS EN 12193:2018 Light and Lighting – Sports Lighting, with respect to limiting light pollution. Any measures put into place to comply with this standard shall remain in place, for the life of the development.

A copy of BS EN 12193:2018 shall be supplied to LPA on request.

Regards

Matthew Rhodes  
Environmental Health Officer (Pollution and Environment)

High Peak Borough Council and Staffordshire Moorlands District Council



\*\*\*\*\*

---

Do you really need to print out this Email? Be green - keep it on the screen.

This email is intended for the addressee(s) only and may contain sensitive, privileged or confidential information that could be protectively marked. If you are not the addressee please do not use the information in any way. If you have received this email in error please notify the sender immediately and delete it from your system. Thank you.

The Council may be required to disclose this email or any responses to it under the Freedom of Information Act 2000. The way in which we handle personal information is set out in our privacy notice and is available at <https://www.highpeak.gov.uk/YourData>

---

---

Do you really need to print out this Email? Be green - keep it on the screen.

This email is intended for the addressee(s) only and may contain sensitive, privileged or confidential information that could be protectively marked. If you are not the addressee please do not use the information in any way. If you have received this email in error please notify the sender immediately and delete it from your system. Thank you.

The Council may be required to disclose this email or any responses to it under the Freedom of Information Act 2000. The way in which we handle personal information is set out in our privacy notice and is available at <https://www.highpeak.gov.uk/YourData>

---