



	Contact Name & Address Paul Birch	Our Reference J910-237/PB/HM
Rachael Simpkin Building Control High Peak Borough Council PO Box 136 Buxton SK17 1AQ	West Area – Buxton Office Buxton Fire & Rescue Centre Staden Lane Buxton Derbyshire SK17 9RZ	Your Reference HPK/2023/0442 Date 14 February 2025

Dear Rachael Simpkin

**TOWN AND COUNTRY PLANNING ACT 1990 (AS AMENDED)
CARPENTER PLC, DINTING LODGE INDUSTRIAL ESTATE, DINTING LANE,
GLOSSOP, SK13 6LE**

I can confirm that Derbyshire Fire and Rescue Service, working on behalf of the Derbyshire Fire and Rescue Authority, have no objections to the erection of solar array, supporting energy infrastructure and associated site works subject to the following:

- Access for emergency service vehicles, both during the demolition and construction phases of the proposal, should be provided in accordance with Approved Document B (Vols 1 and 2) Section B5.
- Site details should be provided to Derbyshire Fire and Rescue Service with contact details and expected timeframes for the build.

If we can be of any further assistance to you in this matter please do not hesitate to contact me.

Yours sincerely

Authorised Fire Safety Inspecting Officer
And on behalf of the Derbyshire Fire and Rescue Authority

email: reception@derbys-fire.gov.uk
www.derbys-fire.gov.uk

Chief Fire Officer / Chief Executive
Rob Taylor

