



High Peak Borough Council

working for our community

17/10/2025

My ref: ESM/DOC/2023/0039

Your ref:

Mr James Dunn
Canal & River Trust
National Waterways Museum
South Pier Road
Ellesmere Port
Cheshire
CH65 4FW

Dear Sir/Madam

**DOC/2023/0039 - Discharge of Condition 44 in relation to application
HPK/2021/0607 at Toddbrook Reservoir Reservoir Road, Whaley Bridge**

44. Details of drainage were submitted under drg no. WBAFC-CRT-25-5-23 Rev P1. The scheme was reviewed by Derbyshire County Council LLFA and noted that the specification for the earthworks and pipe drainage system were acceptable, however note that calculations have not been submitted for the new proposed 150mm drain and that a survey will need to be carried downstream of the connection in order to assess the existing condition, further noting that existing pipes are already damaged. The LLFA further wanted confirmation that if it is confirmed that the pipes are collapsed or severely damaged that they will be replaced or repaired. No further information has been provided subsequent to this request and there is currently insufficient information for the discharge of the planning condition.

The condition is therefore not discharged at the present time. I would be grateful if you could provide the outstanding information at your earliest convenience.

If you have any questions regarding the above or wish to discuss further please contact Eloun.smith@highpeak.gov.uk.

Yours faithfully

31/10/2025

X 

Signed by: Ben Haywood

Head of Development Services

