Door Schedule

Door No.	Location	Fire Rating	Frame Details	Door Finish	Structural opening Approx.	Finishes	Glazing	Glazing Fire Rating Door	Door openings	Ironmongery	Signage	Remark
D01	+061 KIU	FD30s	All doors are specified with a 55mm deep, 32mm wide frame. Glazing 44mm wide frame *(where applicable)*.	solid core oak paneled veneered	840 x 2073	pre-laquered finish	N/A	N/A	As per drawing 52061-CDP-XX-XX-DR-B-5001	Hinge Protection Kits, Stainless steel, 102 x 76 x 3mm. Each door is to have 3 hinges per door. Door closer are to be NHN 80 series or equivalent approved. Oval Mortice Door Knob Antique Brass to be fitted to D01 and D03 Locks to be ASSA compact 3088 deadlock c/w euro double cylinder and Escutcheons to be fitted with lorient lock and latch protection jacket. Threshold to provide 30 min fire rating	Fire door keep shut (on both sides of door).	Door and door sets are to be fit complete with intumescent smoke seals
D02	013 CA	FD30s	All doors are specified with a 55mm deep, 32mm wide frame. Glazing 44mm wide frame *(where applicable)*.	Timber 4mm plywood face or a 4mm mdf face, sanded smooth	1352 x 2040 Stud wall and bulk head to suit existing opening	All doors are to be finished with paint, using Crown paint (or similar approved). Applied in 3no coats; one coat primer, one coat undercoat and one coat gloss. Colours generally to be.BS4800 00A01. colour to be confirmed with the school prior to order.	Pilkington Pyrodur 7mm or similar approved	30 minutes	As per drawing 52061-CDP-XX-XX-DR-B-5001	Hinge Protection Kits, Stainless steel, 102 x 76 x 3mm. Each door is to have 3 hinges per door. Door closer are to be NHN 80 series or equivalent approved. Pull handles to be stainless steel (satin Finished) bolted through. 200-300mm long, 50mm above the lock case on door. Locks to be ASSA compact 3088 deadlock c/w euro double cylinder and Escutcheons to be fitted with lorient lock and latch protection jacket. Threshold to provide 30 min fire rating .	Fire door keep shut (on both sides of door).	Door and door sets are to be fit complete with intumescent smoke seals
D03	058 LI	FD30s	All doors are specified with a 55mm deep, 32mm wide frame. Glazing 44mm wide frame *(where applicable)*.	Timber 4mm plywood face or a 4mm mdf face, sanded smooth	1682 x 2135	All doors are to be finished with paint, using Crown paint (or similar approved). Applied in 3no coats; one coat primer, one coat undercoat and one coat gloss. Colours generally to be.BS4800 00A01. colour to be confirmed with the school prior to order.	Pilkington Pyrodur 7mm or similar approved	30 minutes	As per drawing 52061-CDP-XX-XX-DR-B-5001	Hinge Protection Kits, Stainless steel, 102 x 76 x 3mm. Each door is to have 3 hinges per door. Door closer are to be NHN 80 series or equivalent approved. Oval Mortice Door Knob Antique Brass to be fitted to D01 and D03 Locks to be ASSA compact 3088 deadlock c/w euro double cylinder and Escutcheons to be fitted with lorient lock and latch protection jacket. Threshold to provide 30 min fire rating.	Fire door keep shut (on both sides of door).	Door and door sets are to be fit complete with intumescent smoke seals
D04	027 OFP	FD30s	All doors are specified with a 55mm deep, 32mm wide frame. Glazing 44mm wide frame *(where applicable)*.	Timber 4mm plywood face or a 4mm mdf face, sanded smooth	892 x 2121	All doors are to be finished with paint, using Crown paint (or similar approved). Applied in 3no coats; one coat primer, one coat undercoat and one coat gloss. Colours generally to be.BS4800 00A01. colour to be confirmed with the school prior to order.	Pilkington Pyrodur 7mm or similar approved	30 minutes	As per drawing 52061-CDP-XX-XX-DR-B-5001	Hinge Protection Kits, Stainless steel, 102 x 76 x 3mm. Each door is to have 3 hinges per door. Door closer are to be NHN 80 series or equivalent approved. lever handles to be stainless steel (satin Finished) bolted through. 50mm above the lock case on door. Locks to be ASSA compact 3088 deadlock c/w euro double cylinder and Escutcheons to be fitted with lorient lock and latch protection jacket. Threshold to provide 30 min fire rating.	Fire door keep shut (on both sides of door).	Door and door sets are to be fit complete with intumescent smoke seals
D05	013 CA	FD30s	All doors are specified with a 55mm deep, 32mm wide frame. Glazing 44mm wide frame *(where applicable)*.	Timber 4mm plywood face or a 4mm mdf face, sanded smooth	1352 x 2040 Stud wall and bulk head to suit existing opening	All doors are to be finished with paint, using Crown paint (or similar approved). Applied in 3no coats; one coat primer, one coat undercoat and one coat gloss. Colours generally to be.BS4800 00A01. colour to be confirmed with the school prior to order.	Pilkington Pyrodur 7mm or similar approved	30 minutes	As per drawing 52061-CDP-XX-XX-DR-B-5001	Hinge Protection Kits, Stainless steel, 102 x 76 x 3mm. Each door is to have 3 hinges per door. Door closer are to be NHN 80 series or equivalent approved. Pull handles to be stainless steel (satin Finished) bolted through. 200-300mm long, 50mm above the lock case on door. Locks to be ASSA compact 3088 deadlock c/w euro double cylinder and Escutcheons to be fitted with lorient lock and latch protection jacket. Threshold to provide 30 min fire rating and to be installed on kitchen door.	Fire door keep shut (on both sides of door).	Door and door sets are to be fit complete with intumescent smoke seals
D06	025 OF	FD30s	All doors are specified with a 55mm deep, 32mm wide frame. Glazing 44mm wide frame *(where applicable)*.	Timber 4mm plywood face or a 4mm mdf face, sanded smooth	740 x 1960	All doors are to be finished with paint, using Crown paint (or similar approved). Applied in 3no coats; one coat primer, one coat undercoat and one coat gloss. Colours generally to be.BS4800 00A01. colour to be confirmed with the school prior to order.	Pilkington Pyrodur 7mm or similar approved	30 minutes	As per drawing 52061-CDP-XX-XX-DR-B-5001	Hinge Protection Kits, Stainless steel, 102 x 76 x 3mm. Each door is to have 3 hinges per door. Door closer are to be NHN 80 series or equivalent approved. Pull handles to be stainless steel (satin Finished) bolted through. 200-300mm long, 50mm above the lock case on door. Locks to be ASSA compact 3088 deadlock c/w euro double cylinder and Escutcheons to be fitted with lorient lock and latch protection jacket. Threshold to provide 30 min fire rating and to be installed on kitchen door.	Fire door keep shut (on both sides of door).	Door and door sets are to be fit complete with intumescent smoke seals
D07	019 CA	FD30s	All doors are specified with a 55mm deep, 32mm wide frame. Glazing 44mm wide frame *(where applicable)*.	Timber 4mm plywood face or a 4mm mdf face, sanded smooth	1932 x 1602	All doors are to be finished with paint, using Crown paint (or similar approved). Applied in 3no coats; one coat primer, one coat undercoat and one coat gloss. Colours generally to be.BS4800 00A01. colour to be confirmed with the school prior to order.	Pilkington Pyrodur 7mm or similar approved	30 minutes	As per drawing 52061-CDP-XX-XX-DR-B-5001	Hinge Protection Kits, Stainless steel, 102 x 76 x 3mm. Each door is to have 3 hinges per door. Door closer are to be NHN 80 series or equivalent approved. Pull handles to be stainless steel (satin Finished) bolted through. 200-300mm long, 50mm above the lock case on door. Locks to be ASSA compact 3088 deadlock c/w euro double cylinder and Escutcheons to be fitted with lorient lock and latch protection jacket. Threshold to provide 30 min fire rating and to be installed on kitchen door.	Fire door keep shut (on both sides of door).	Door and door sets are to be fit complete with intumescent smoke seals

Door Schedule

DISCLAIMER: THE CONTRACTOR MUST CHECK AND VERIFY ALL DIMENSIONS AND LEVELS ON SITE BEFORE PLACING ANY ORDERS OR COMMENCEMENT OF THE WORKS ON SITE. ALL DISCREPANCIES MUST BE BROUGHT TO THE IMMEDIATE ATTENTION OF THE CONTRACT ADMINISTRATOR. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ANY RELEVANT ARCHITECT, ENGINEER OR SPECIALIST DRAWINGS, DETAILS AND SPECIFICATIONS ISSUED UNDER THIS CONTRACT.

© CONCERTUS DESIGN AND PROPERTY

CONSULTANTS

REV	DATE	DESCRIPTION	DRAWN	CHKD
A	28/01/26	First Issue	MN	SS

Concertus
Part of the Wertas Group
2 Friars Bridge Road, Ipswich, IP1 1RR 01473 316 650 www.concertus.co.uk

PROJECT
New Mills School
FRA Works

CLIENT
Derbyshire County Council

DRAWING TITLE
Door Schedule

STATUS S4 PURPOSE OF ISSUE FOR PRICING SCALE 1:100 @ A0

525061-CDP-XX-XX-DR-B-7001
project number - originator - volume/system - level/location -type - role - number - rev