



SMOKE DETECTION

Provide a linked smoke alarm detection system to BS EN 14604 and BS 5839-6:2019 to at least a Grade D2 category LD3 standard (Grade A for large house, Grade A, LD2 for large house with 3 stories or more). System to be mains powered with battery back up. At least one smoke detector to be provided in each hallway and landing. In hallways exceeding 7.5m in length, no point within the hallway should exceed 7.5m from the nearest detector and no bedroom door should be further than 3m from the nearest smoke alarm. If ceiling mounted they should be 300mm from the walls and light fittings. Mains-wired, interlinked heat detector to be provided to the kitchen and smoke detectors to principal living rooms, if required by Building Control.



Revision	Description
Location Mr & Mrs 3 Jubilee Gardens High Peak SK22 4PL	
Title Proposed Plans and Elevations	
Scale	Drawing No. As indicated @A1 25001 P04
Revision	