

From: EHealth Consultation
Sent: 10 April 2026 14:54
To: Planning (HPBC)
Cc: Stuart Talbot
Subject: DOC/2026/0021 - Environmental Health Consultation#

Hi Stuart

Application number	DOC/2026/0021	Application type	Discharge of conditions
Site address	Glossop Padel Centre , 130 Woolley Bridge , Hadfield , Glossop , Derbyshire , SK13 2NX	Proposal	Discharge of Condition 4 in relation to HPK/2025/0354

Advice to LPA

The above application for discharge of condition 4 from HPK/2025/0352 has been forwarded to Environmental Health for consideration.

4. Prior to the use hereby approved being brought into use, a scheme of sound insulation shall be submitted to and approved in writing by the Local Planning Authority. The scheme shall demonstrate best practice for the reduction in noise, that may affect local amenity. The approved scheme shall thereafter be installed prior to the development being first brought into use and maintained for the life of the development.

It's recommended that the application to discharge condition 4 is refused, as the information provided is not sufficient.

The scheme should be detailed within a single written report and should begin by identifying potential noise sources associated with padel then explain how these noise sources are to be mitigated against. Where sound insulation is used a sound reduction index value (Rw) should be quoted for the individual element, along with the real-life sound reduction predicted (DnT,w) from inside the building to outside.

Estimated noise levels during a game will be required, both as a LAeq and Lmax

I imagine the principal source of neighbourhood noise will be from the ball striking the building cladding; although I know very little about padel as a sport. The applicant may be best advised seeking the advice of a suitable noise consultant with experience of noise from padel courts.

Regards

Matthew Rhodes
Environmental Health Officer (Pollution and Environment)

High Peak Borough Council and Staffordshire Moorlands District Council

www.highpeak.gov.uk | Follow HPBC on [Twitter](#) | [Facebook](#)



Do you really need to print out this Email? Be green - keep it on the screen.

This email is intended for the addressee(s) only and may contain sensitive, privileged or confidential information that could be protectively marked. If you are not the addressee please do not use the information in any way. If you have received this email in error please notify the sender immediately and delete it from your system. Thank you.

The Council may be required to disclose this email or any responses to it under the Freedom of Information Act 2000. The way in which we handle personal information is set out in our privacy notice and is available at <https://www.highpeak.gov.uk/YourData>
