



Building Control
High Peak Borough Council
PO Box 136
Buxton
SK17 1AQ

Contact Name & Address

Neil Hibberd

Our Reference

J999-177/NHi/HM

Your Reference

HPK/2026/0141

Date

27 April 2026

West Area - Buxton Office
Buxton Fire & Rescue Centre
Staden Lane
Buxton
Derbyshire
SK17 9RZ

Contact Telephone No

[REDACTED]

Contact Email

[REDACTED]

Dear Planning

TOWN AND COUNTRY PLANNING ACT 1990 (AS AMENDED)
LAND AT MIRY MEADOW, STATION ROAD, CHAPEL-EN-LE-FRITH, SK23 9RU

I can confirm that Derbyshire Fire and Rescue Service, working on behalf of the Derbyshire Fire and Rescue Authority, have no objections to the erection of 24no dwellings alongside access, car parking, landscaping and associated works, subject to the following:

- Access for emergency service vehicles, both during the demolition and construction phases of the proposal, should be provided in accordance with Approved Document B (Vols 1 and 2) Section B5.
- Site details should be provided to Derbyshire Fire and Rescue Service with contact details and expected timeframes for the build.

If we can be of any further assistance to you in this matter please do not hesitate to contact me.

Yours faithfully

[REDACTED]

Authorised Fire Safety Inspecting Officer
And on behalf of the Derbyshire Fire and Rescue Authority

email [REDACTED]
www.derbys-fire.gov.uk

Chief Fire Officer / Chief Executive
Mick Sharman



EMPLOYER RECOGNITION SCHEME

GOLD AWARD 2022

Proudly supporting those who serve