

From: EHealth Consultation
Sent: 28 August 2026 11:56
To: Planning (HPBC)
Cc: Alex Bonser
Subject: DOC/2026/0053 - Environmental Health Consultation#

Hi Alex

Application number	DOC/2026/0053	Application type	Discharge of conditions
Site address	LAND WEST OF , Buxton Road , Dove Holes , Derbyshire ,	Proposal	Discharge of conditions 3, 9 and 17 relating to HPK/2024/0467

The site layout plan is unreadable, a resolution-independent vector plan (pdf) is required.

Conditions 3, 9 and 17 don't directly relate to Env Health recommended conditions, although condition 3 impacts the acoustic barrier. The barrier must comply with condition 4 (with noise mitigation as detailed in the Noise Assessment Ref R10732-1 Rev 1); and should have a minimum superficial weight of 15 kg/m2 with a minimum height of 2.4 m above local ground level.

I can confirm that High Peak Borough Council, Environmental Health have no further observations to make concerning this DOC application.

Regards

Matthew Rhodes
Environmental Health Officer (Pollution and Environment)

High Peak Borough Council and Staffordshire Moorlands District Council

Mobile:

www.highpeak.gov.uk | Follow HPBC on [Twitter](#) | [Facebook](#)

www.staffsmoorlands.gov.uk | Follow SMDC on [Twitter](#) | [Facebook](#)



Do you really need to print out this Email? Be green - keep it on the screen.

This email is intended for the addressee(s) only and may contain sensitive, privileged or confidential information that could be protectively marked. If you are not the addressee please do not use the information in any way. If you have received this email in error please notify the sender immediately and delete it from your system. Thank you.

The Council may be required to disclose this email or any responses to it under the Freedom of Information Act 2000. The way in which we handle personal information is set out in our privacy notice and is available at <https://www.highpeak.gov.uk/YourData>
